

Maintenance Certificate

Name Nutfield Church Primary School
Address 59 Mid Street
South Nutfield
Surrey

Postcode RH1 4JJ

Job Ref: 443456

Engineer Clive Hearn

Arrived 15/02/23 09:06

Left 15/02/23 10:06

Our Ref: NUTFIE::
Installation: A) Intruder Alarm System
Premises: C) Public Sector
Signalling: E) BT RedCARE
Order No:
Reason for Visit: Routine Maintenance Visit
Call Out Charge 0.00
Materials 0.00
Other 0.00
Total Ex VAT: 0.00

Findings and Action Taken:

Rm Routine Maintenance: all checks completed all ok.

Outstanding company action:

[25/05/18] [10/02/15]
[10/02/15] [27/02/15] [21/05/15]

[10/02/15] [27/02/15][10/02/15]

[There were no disconnections on this visit.](#)

[There were no isolations on this visit.](#)

Checks carried out:

1 Check the installation, location and siting of all equipment against the specification and is fitted to the relevant standards stated on the specification

2 Check the satisfactory operation of all detection devices

3 Check the satisfactory operation of all deliberately operated devices

4 Check that the battery requirements meet the fitted regulation as stated on the specification

5 Check mains and standby power supplies including correct charging and standby rates

6 Check control unit for correct operation

7 Check remote signalling equipment (intelligibility to be ascertained)

8 Test signalling equipment to central station

9 Setting procedure tested where possible along with any part sets

10 Engineer's copy of specification and or drawings marked up and left in control panel (where appropriate). Copies to be sent to office

11 Check operation of all audible warning devices for correct operation

12 Check alarm system is fully operational

13 Panel Voltage
13.72

14 Panel mA
416

15 PSU Voltage 1
13.66

16 PSU mA 1
287

17 PSU Voltage 2
13.90

18 PSU mA 2
166

19 PSU Voltage 3
13.75

20 PSU mA 3
185

21 PSU Voltage 4

22 PSU mA 4

23 PSU Voltage 5

24 PSU mA 5

25 PSU Voltage 6

26 PSU mA 6

27 PSU Voltage 7

28 PSU mA 7

29 PSU Voltage 8

30 PSU mA 8

31 PSU Voltage 9

32 PSU mA 9

Clive Hearn

Signed by client:



Carried out by: Clive Hearn

Fred at 15/02/23 10:06

Visit us at:
admiralsecurity.co.uk

info@admiralsecurity.co.uk
01737 855 900 (Surrey) / 01444 440 184 (Sussex)

Trading address: Office F3, Robert Denholm House, Bletchingley Road, South Nutfield, Surrey, RH1 4HW

Registered address: 2, Effingham Road, Reigate, Surrey, RH2 7JN

Registered in England & Wales No. 2722048. VAT No. 602 4307 88

Directors: Andrew Austin, Phillip Burchell, Andrew Gerrard

