



Boiler Room Inspection Service Record

Job Number 39895

Registered Business Details		Site Address		Landlord or Agent	
Engineer Name:	Joe Milsom	Name/Company:	Nutfield Primary School	Name/Company:	Nutfield Primary School
Gas Safe Register No:	5230884	Site Name:	Main address	Address:	Main address, 59 Mid Street, South Nutfield, Redhill, Surrey
Company:	Advanced Control Solutions Ltd	Address:	59 Mid Street, South Nutfield, Redhill, Surrey	Postcode:	RH1 4JJ
Address:	7 Bakersgate Courtyard, Ash Road, Pirbright, Surrey	Postcode:	RH1 4JJ	Tel:	01737 823239
Postcode:	GU24 0NJ	Tel:	01737 823239		
Tel:	01483 237812	Email:	N/A		
Email:	N/A				
Web site:	N/A				

Appliance Details (max 8 appliances)				
Location	Type	Make	Model	Serial No
Boiler Room	Hot water Expansion	Aquasystem	AR35	Z2063885
Main Plant Room	Pump	Grundfos	PC0608	96408936
Main Plant Room	Pressurisation unit	Boss	MX2-3E	03510039

Reading								
Appliance No	1	2	3	4	5	6	7	8
Condition (1-5)	5	5	5	N/A	N/A	N/A	N/A	N/A
Electrical supply checked	N/A	Yes	Yes	N/A	N/A	N/A	N/A	N/A
Checked for leaks	Yes	Yes	Yes					
Pressure Switches checked	N/A	N/A	Yes	N/A	N/A	N/A	N/A	N/A
Pump Operation checked	N/A	Yes	N/A	N/A	N/A	N/A	N/A	N/A
Clear of alarms	N/A	N/A	Yes	N/A	N/A	N/A	N/A	N/A
Approximate age	6	14	1	N/A	N/A	N/A	N/A	N/A
Pressure rating	3.5bar	N/A	10bar	N/A	N/A	N/A	N/A	N/A
Stability	Pass	Pass	Pass	N/A	N/A	N/A	N/A	N/A
Isolation present	Yes	Yes	Yes	N/A	N/A	N/A	N/A	N/A
Vessel drained	Yes	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Pressure checked	Yes	Yes	Yes	N/A	N/A	N/A	N/A	N/A
Pressure adjusted	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Cleaned basket	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Reinstated	Yes	Yes	Yes	N/A	N/A	N/A	N/A	N/A
Operational	Yes	Yes	Yes	N/A	N/A	N/A	N/A	N/A
Volume/Capacity	3bar	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Size	N/A	35l	N/A	N/A	N/A	N/A	N/A	N/A



Boiler Room Inspection Service Record

Job Number 39895

Faults Identified

N/A

Remedial Action Taken

N/A

General Comments

Drained and recharged Vessel, tested operation of pumps, Checked pressurisation Unit is working correctly, all tested OK.

Declaration of Service Record

I confirm that all of the above work described on this form has been satisfactorily completed in accordance with the British Standards and the manufacturer's instructions.

Customer Signature

Customer Print Name

Engineers Signature

Engineer Print Name

COVID 19

covid 19

Date

18/08/2022

J M

Joe Milsom

Date

18/08/2022