

Maintenance Certificate

Name	Nutfield Church Primary School	Our Ref:	NUTFIE::
Address	59 Mid Street South Nutfield Surrey	Installation:	A) Intruder Alarm System
		Premises:	C) Public Sector
		Signalling:	E) BT RedCARE
		Order No:	
Postcode	RH1 4JJ	Reason for Visit:	Routine Maintenance Visit
Job Ref:	440533	Call Out Charge	0.00
Engineer	Josh Savery	Materials	0.00
Called	10/07/22 16:57	Other	0.00
Arrived	29/07/22 10:24	Total Ex VAT:	0.00
Left	29/07/22 11:18		

Findings and Action Taken:

Rm Routine Maintenance. All checks complete. Signals all ok

Outstanding company action:

[25/05/18] [10/02/15] [10/02/15] [27/02/15] [21/05/15] [10/02/15] [27/02/15][10/02/15]

There were no disconnections on this visit.

There were no isolations on this visit.

Checks carried out:	appropriate). Copies to be sent to office	23 PSU Voltage 5	N/A
1 Check the installation, location and siting of all equipment against the specification and is fitted to the relevant standards stated on the specification	11 Check operation of all audible warning devices for correct operation	24 PSU mA 5	N/A
2 Check the satisfactory operation of all detection devices	12 Check alarm system is fully operational	25 PSU Voltage 6	N/A
3 Check the satisfactory operation of all deliberately operated devices	13 Panel Voltage	26 PSU mA 6	N/A
4 Check that the battery requirements meet the fitted regulation as stated on the specification	14 Panel mA	27 PSU Voltage 7	N/A
5 Check mains and standby power supplies including correct charging and standby rates	15 PSU Voltage 1	28 PSU mA 7	N/A
6 Check control unit for correct operation	16 PSU mA 1	29 PSU Voltage 8	N/A
7 Check remote signalling equipment (intelligibility to be ascertained)	17 PSU Voltage 2	30 PSU mA 8	N/A
8 Test signalling equipment to central station	18 PSU mA 2	31 PSU Voltage 9	N/A
9 Setting procedure tested where possible along with any part sets	19 PSU Voltage 3	32 PSU mA 9	N/A
10 Engineer's copy of specification and or drawings marked up and left in control panel (where	20 PSU mA 3		
	21 PSU Voltage 4	Readings:	
	22 PSU mA 4		

Signed on behalf of customer by:
Freddie at 29/07/22 11:16

Signature facsimile:

Printed: 14/08/22 14:56 by AG

