

FAO Bursar
Nutfield Church C of E Primary School
Mid Street
South Nutfield
RH1 4JJ



SES Water
London Road
Redhill, Surrey,
RH1 1LJ
Telephone: 01737 772000
Facsimile: 01737 766807
Website: www.seswater.co.uk
Email: contactus@seswater.co.uk

30th October 2023

Job Number: J08GCU

To Whom It May Concern,

Further to our recent visit to the above premises, as part of the Company's programme to enforce the Regulations, we carried out a Water Fittings Regulations Inspection on this property.

The inspection of the property has identified contraventions/issues that require rectification to ensure that the water supply remains wholesome, and waste does not occur. Details of these contraventions/issues and the remedial work required to resolve them are provided in the report enclosed.

Each contravention in the report has a risk associated to it, which ranges from 5 being the most serious risk with potential to cause serious harm to health, down to 2 being a minor risk. Contraventions that could result in the waste of water are listed separately.

Please be aware that where zonal backflow protection has been installed for fittings associated with the highest risk categories (4 and 5), secondary backflow protection may also be required. This is to prevent cross contamination between fittings downstream of the zonal protection point.

It is essential that the contraventions detailed on the attached schedule are rectified by **26th January 2024**. We have therefore arranged for our Regulations Specialist to re-attend on **29th January 2024** at **10am** to verify that the premises is fully compliant.

I would be grateful if you could please acknowledge receipt of this letter and confirm whether the above appointment date and time is agreeable to you.

If in the meantime you would like any further information or advice regarding this matter, you can email us at waterregulations@seswater.co.uk

Yours sincerely,

Laura Knowles
Regulations Enforcement Officer
Enc.