

# SERVICE INSPECTION CERTIFICATE: FIRE ALARM & EMERGENCY LIGHTING

## RJ Fire

### Fire & Security Specialists

32 Cinnabar Drive  
Sittingbourne  
Kent ME10 5LA

CLIENT  
FINANCE OFFICE  
NUTFIELD C/E SCHOOL  
59 MID STREET  
SOUTH NUTFIELD  
RH1 4JJ

**CERTIFICATE NO:3193**

WORKS REF NO:

| INSPECTION DATE:  | SERVICE INSPECTIONS AT:                | SERVICE INSPECTIONS: | NEXT SERVICE:       |
|-------------------|----------------------------------------|----------------------|---------------------|
| <b>04/04/2023</b> | NUTFIELD SCHOOL SOUTH NUTFIELD RH1 4JJ | BI ANNUAL            | <b>OCTOBER 2023</b> |

| DISCIPLINES:              | SERVICE & MAINTENANCE CARRIED OUT:                                             |      |      |
|---------------------------|--------------------------------------------------------------------------------|------|------|
| FIRE ALARM:<br>E/LIGHTING |                                                                                | PASS | FAIL |
| SYSTEM TESTS              |                                                                                | YES  |      |
| CONTROL PANEL             | Operational (EDA ZERIO PLUS RADIO SYSTEM)                                      | YES  |      |
| SMOKE DETECTORS           | Operational (EDA OPTICAL DETECTORS)                                            | YES  |      |
| HEAT DETECTORS            | Operational (EDA RATE OF RISE DETECTORS)                                       | YES  |      |
| CALL POINTS               | Operational (EDA)                                                              | YES  |      |
| BELLS/SOUNDERS            | Operational (ZERIO COMBINED BASE SOUNDERS)                                     | YES  |      |
| EMERGENCY LIGHTING        |                                                                                |      |      |
| BEACONS                   | Operational                                                                    | YES  |      |
| RELAYS                    | N/A                                                                            |      |      |
| INTERLINKS                | N/A                                                                            |      |      |
| BEAMS                     | N/A                                                                            |      |      |
| DIALLER                   | N/A                                                                            |      |      |
| REMEDIAL WORKS            |                                                                                |      |      |
| ZONE CHART                |                                                                                | YES  |      |
| BATTERIES                 | Operational (SOME DETECTORS REQUIRE NEW BATTERIES TO BE REPLACED BY CARETAKER) | YES  |      |
| LOG BOOK SIGNED           |                                                                                |      |      |
| SERVICE COMPLETE          |                                                                                | YES  |      |

SERVICE ENGINEER:

R.Jones