

SERVICE INSPECTION CERTIFICATE: FIRE ALARM & EMERGENCY LIGHTING

RJ Fire

Fire & Security Specialists

32 Cinnabar Drive
Sittingbourne
Kent ME10 5LA

CLIENT
FINANCE OFFICE
NUTFIELD C/E SCHOOL
59 MID STREET
SOUTH NUTFIELD
RH1 4JJ

CERTIFICATE NO:2885

WORKS REF NO:

INSPECTION DATE:	SERVICE INSPECTIONS AT:	SERVICE INSPECTIONS:	NEXT SERVICE:
27.07.2022	NUTFIELD SCHOOL SOUTH NUTFIELD RH1 4JJ	BI ANNUAL	FEBRUARY 2023

DISCIPLINES:	SERVICE & MAINTENANCE CARRIED OUT:		
FIRE ALARM: E/LIGHTING		PASS	FAIL
SYSTEM TESTS		YES	
CONTROL PANEL	Operational (EDA ZERIO PLUS RADIO SYSTEM)	YES	
SMOKE DETECTORS	Operational (EDA OPTICAL DETECTORS)	YES	
HEAT DETECTORS	Operational (EDA RATE OF RISE DETECTORS)	YES	
CALL POINTS	Operational (EDA)	YES	
BELLS/SOUNDERS	Operational (ZERIO COMBINED BASE SOUNDERS)	YES	
EMERGENCY LIGHTING	ANNUAL DISCHARGE TEST X2 FAILED X1 YR3 & X1 YR4	YES	
BEACONS	Operational	YES	
RELAYS	N/A		
INTERLINKS	N/A		
BEAMS	N/A		
DIALLER	N/A		
REMEDIAL WORKS			
ZONE CHART		YES	
BATTERIES	Operational (SOME DETECTORS REQUIRE NEW BATTERIES TO BE REPLACED: BATTERIES ON ORDER)	YES	
LOG BOOK SIGNED			
SERVICE COMPLETE		YES	

SERVICE ENGINEER:

R.Jones