

SITE VISIT RECORD

NUTFIELD CHURCH PRIMARY

SCHOOL UPRN:874

OUR REFERENCE O 125159/1
YOUR REFERENCE 121022.00.
ENGINEERS Connor McMann Sebastien Louis-Verdier
VISIT DATE 31-07-2023

SCOPE OF WORK

28 x Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned) |
10 x Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned) |
2 x Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned) |
27 x Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned) |
4 x Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned) |
1 x Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Engineer: Green Card

Completed site based risk card prior to starting / mobilising any work to determine all risk that may exist on site. **Completed Risk Card**

General Comment -

Check-In	Check-Out	Engineer	Site Rep
 10:15 AM 31-07-2023	 15:41 PM 31-07-2023	 Connor McMann	

Check-In	Check-Out	Engineer	Site Rep
 10:15 AM 31-07-2023	 14:00 PM 31-07-2023	Sebastien Louis-Verdier	

SITE Nutfield Church Primary School UPRN:874

Mid Street
Redhill
RH1 4JJ

CLIENT Surrey County Council

CONTACT SURREY HELPDESK ()

Cockshot Road
Reigate
Surrey
RH2 8BF

EXECUTIVE SUMMARY

Non-conformance records

TOTAL: 0

No NCRs tracked during the visit.

SUMMARY TABLE

Asset Type: Outlet: Cold Water

Asset Location	Asset Number	Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)
Basin / School / Ground Floor / Kitchen Staff Toilet / Basin	CWO_000027	Manually cleaned, descaled and disinfected
Drinking Fountain / School / Ground Floor / Reception Class / Drinking Fountain	CWO_000003	Manually cleaned, descaled and disinfected
Sink / School / Ground Floor / Staff Room / Sink	CWO_000028	Manually cleaned, descaled and disinfected
Drinking Fountain / School / Ground Floor / Year 1 class / Drinking Fountain	CWO_000006	Manually cleaned, descaled and disinfected
LHS Basin / School / Ground Floor / Year 3 class / LHS Basin	CWO_000012	Manually cleaned and descaled
RHS Basin / School / Ground Floor / Year 3 class / RHS Basin	CWO_000013	Manually cleaned and descaled
Sink / School / Ground Floor / Year 3 class / Sink	CWO_000011	Manually cleaned, descaled and disinfected
LHS Basin / School / Ground Floor / Year 5 class / LHS Basin	CWO_000016	Manually cleaned, descaled and disinfected
RHS Basin / School / Ground Floor / Year 5 class / RHS Basin	CWO_000015	Manually cleaned, descaled and disinfected
Sink / School / Ground Floor / Year 5 class / Sink	CWO_000017	Manually cleaned, descaled and disinfected

Asset Type: Outlet: Cold Water (Non-Sentinel)

Asset Location	Asset Number	Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)
LHS Basin / School / Ground Floor / Aquarium / LHS Basin	CWONS_000049	Manually cleaned, descaled and disinfected
RHS Basin / School / Ground Floor / Aquarium / RHS Basin	CWONS_000048	Manually cleaned, descaled and disinfected
Sink / School / Ground Floor / Cleaners by year 5 / Sink	CWONS_000051	Manually cleaned, descaled and disinfected
Basin / School / Ground Floor / Disabled Toilet / Basin	CWONS_000045	Manually cleaned, descaled and disinfected
Sink Front / School / Ground Floor / Food tech / Sink Front	CWONS_000055	Manually cleaned, descaled and disinfected
Sink Rear / School / Ground Floor / Food tech / Sink Rear	CWONS_000056	Manually cleaned, descaled and disinfected
LHS / School / Ground Floor / Kitchen / Double Sink / LHS	CWONS_000063	Manually cleaned, descaled and disinfected
RHS / School / Ground Floor / Kitchen / Double Sink / RHS	CWONS_000064	Manually cleaned, descaled and disinfected
Pot Wash Sink / School / Ground Floor / Kitchen / Pot Wash Sink	CWONS_000062	Manually cleaned, descaled and disinfected

Asset Location	Asset Number	Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)
Outside Reception Class / School / Ground Floor / Outside Reception Class	CWONS_000040	Manually cleaned, descaled and disinfected
Outside Year 2 / School / Ground Floor / Outside Year 2	CWONS_000050	Manually cleaned and descaled
Outside Year 3 / School / Ground Floor / Outside Year 3	CWONS_000057	Manually cleaned and descaled
	CWONS_000058	Manually cleaned and descaled
LHS Basin / School / Ground Floor / Reception Class / LHS Basin	CWONS_000061	Manually cleaned, descaled and disinfected
RHS Basin / School / Ground Floor / Reception Class / RHS Basin	CWONS_000065	Manually cleaned, descaled and disinfected
LHS Basin / School / Ground Floor / Staff Ladies Toilet / LHS Basin	CWONS_000060	Manually cleaned, descaled and disinfected
RHS Basin / School / Ground Floor / Staff Ladies Toilet / RHS Basin	CWONS_000059	Manually cleaned, descaled and disinfected
LHS Basin / School / Ground Floor / Year 1 class / LHS Basin	CWONS_000066	Manually cleaned, descaled and disinfected
RHS Basin / School / Ground Floor / Year 1 class / RHS Basin	CWONS_000067	Manually cleaned, descaled and disinfected
LHS Basin / School / Ground Floor / Year 2 class / Basin / LHS Basin	CWONS_000042	Manually cleaned, descaled and disinfected
RHS Basin / School / Ground Floor / Year 2 class / Basin / RHS Basin	CWONS_000041	Manually cleaned, descaled and disinfected
LHS / School / Ground Floor / Year 4 Boys Toilet / LHS	CWONS_000046	Manually cleaned, descaled and disinfected
RHS / School / Ground Floor / Year 4 Boys Toilet / RHS	CWONS_000047	Manually cleaned, descaled and disinfected
LHS / School / Ground Floor / Year 4 girls toilet / LHS	CWONS_000043	Manually cleaned, descaled and disinfected
RHS / School / Ground Floor / Year 4 girls toilet / RHS	CWONS_000044	Manually cleaned, descaled and disinfected
LHS Basin / School / Ground Floor / Year 6 class / LHS Basin	CWONS_000054	Manually cleaned, descaled and disinfected
RHS Basin / School / Ground Floor / Year 6 class / RHS Basin	CWONS_000053	Manually cleaned, descaled and disinfected
Sink / School / Ground Floor / Year 6 class / Sink	CWONS_000052	Manually cleaned, descaled and disinfected

Asset Type: Outlet: Cold Water (Sentinel)

Asset Location	Asset Number	Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)
Basin / School / Ground Floor / Kitchen / Basin	CWOSEN_000024	Manually cleaned, descaled and disinfected

Asset Type: Outlet: Hot Water

Asset Location	Asset Number	Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)
Basin / School / Ground Floor / Kitchen Staff Toilet / Basin	HWO_000025	Manually cleaned, descaled and disinfected
Sink / School / Ground Floor / Staff Room / Sink	HWO_000026	Manually cleaned, descaled and disinfected

Asset Type: Outlet: Hot Water (Non-Sentinel)

Asset Location	Asset Number	Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)
LHS Basin / School / Ground Floor / Aquarium / LHS Basin	HWONS_000037	Manually cleaned, descaled and disinfected
RHS Basin / School / Ground Floor / Aquarium / RHS Basin	HWONS_000036	Manually cleaned, descaled and disinfected
Sink / School / Ground Floor / Cleaners by year 5 / Sink	HWONS_000025	Manually cleaned, descaled and disinfected
Basin / School / Ground Floor / Disabled Toilet / Basin	HWONS_000033	Manually cleaned, descaled and disinfected
Sink Front / School / Ground Floor / Food tech / Sink Front	HWONS_000027	Manually cleaned, descaled and disinfected
Sink Rear / School / Ground Floor / Food tech / Sink Rear	HWONS_000021	Manually cleaned, descaled and disinfected
LHS / School / Ground Floor / Kitchen / Double Sink / LHS	HWONS_000024	Manually cleaned, descaled and disinfected
RHS / School / Ground Floor / Kitchen / Double Sink / RHS	HWONS_000023	Manually cleaned, descaled and disinfected
Pot Wash Sink / School / Ground Floor / Kitchen / Pot Wash Sink	HWONS_000030	Manually cleaned, descaled and disinfected
LHS Basin / School / Ground Floor / Reception Class / LHS Basin	HWONS_000045	Manually cleaned, descaled and disinfected
RHS Basin / School / Ground Floor / Reception Class / RHS Basin	HWONS_000044	Manually cleaned, descaled and disinfected
LHS Basin / School / Ground Floor / Staff Ladies Toilet / LHS Basin	HWONS_000031	Manually cleaned, descaled and disinfected
RHS Basin / School / Ground Floor / Staff Ladies Toilet / RHS Basin	HWONS_000032	Manually cleaned, descaled and disinfected
LHS Basin / School / Ground Floor / Year 1 class / LHS Basin	HWONS_000043	Manually cleaned, descaled and disinfected
RHS Basin / School / Ground Floor / Year 1 class / RHS Basin	HWONS_000042	Manually cleaned, descaled and disinfected
LHS Basin / School / Ground Floor / Year 2 class / Basin / LHS Basin	HWONS_000040	Manually cleaned, descaled and disinfected
RHS Basin / School / Ground Floor / Year 2 class / Basin / RHS Basin	HWONS_000041	Manually cleaned, descaled and disinfected
LHS / School / Ground Floor / Year 4 Boys Toilet / LHS	HWONS_000034	Manually cleaned, descaled and disinfected
RHS / School / Ground Floor / Year 4 Boys Toilet / RHS	HWONS_000035	Manually cleaned and descaled

Asset Location	Asset Number	Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)
LHS / School / Ground Floor / Year 4 girls toilet / LHS	HWONS_000039	Manually cleaned, descaled and disinfected
RHS / School / Ground Floor / Year 4 girls toilet / RHS	HWONS_000038	Manually cleaned, descaled and disinfected
LHS Basin / School / Ground Floor / Year 5 class / LHS Basin	HWONS_000015	Manually cleaned, descaled and disinfected
RHS Basin / School / Ground Floor / Year 5 class / RHS Basin	HWONS_000026	Manually cleaned, descaled and disinfected
Sink / School / Ground Floor / Year 5 class / Sink	HWONS_000028	Manually cleaned, descaled and disinfected
LHS Basin / School / Ground Floor / Year 6 class / LHS Basin	HWONS_000047	Manually cleaned, descaled and disinfected
RHS Basin / School / Ground Floor / Year 6 class / RHS Basin	HWONS_000046	Manually cleaned, descaled and disinfected
Sink / School / Ground Floor / Year 6 class / Sink	HWONS_000029	Manually cleaned, descaled and disinfected

Asset Type: Outlet: Hot Water (Sentinel)

Asset Location	Asset Number	Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)
Basin / School / Ground Floor / Kitchen / Basin	HWOSEN_000022	Manually cleaned, descaled and disinfected
LHS Basin / School / Ground Floor / Year 3 class / LHS Basin	HWOSEN_000023	Manually cleaned and descaled
RHS Basin / School / Ground Floor / Year 3 class / RHS Basin	HWOSEN_000024	Manually cleaned and descaled
Sink / School / Ground Floor / Year 3 class / Sink	HWOSEN_000025	Manually cleaned, descaled and disinfected

LOGBOOK

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000049) Q / SCHOOL / GROUND FLOOR / AQUARIUM / LHS BASIN		
Type of Asset: Basin/Sink Is this outlet a sentinel?: No What is this outlet fed by?: Mains Supply pipe material: Copper Size of supply pipe: 15		
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)		Manually cleaned, descaled and disinfected
OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000037) Q / SCHOOL / GROUND FLOOR / AQUARIUM / LHS BASIN		
Type of Asset: Basin/Sink Is this outlet a sentinel?: No Is the outlet fed by a TMV?: Yes Is the outlet a mixer tap?: No Supply pipe material: Copper Size of supply pipe: 15		
Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)		Manually cleaned, descaled and disinfected
OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000048) Q / SCHOOL / GROUND FLOOR / AQUARIUM / RHS BASIN		
Type of Asset: Basin/Sink Is this outlet a sentinel?: No What is this outlet fed by?: Mains Supply pipe material: Copper Size of supply pipe: 15		
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)		Manually cleaned, descaled and disinfected
OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000036) Q / SCHOOL / GROUND FLOOR / AQUARIUM / RHS BASIN		
Type of Asset: Basin/Sink Is this outlet a sentinel?: No Is the outlet fed by a TMV?: Yes Is the outlet a mixer tap?: No Supply pipe material: Copper Size of supply pipe: 15		
Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)		Manually cleaned, descaled and disinfected
OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000051) Q / SCHOOL / GROUND FLOOR / CLEANERS BY YEAR 5 / SINK		
Type of Asset: Basin/Sink Is this outlet a sentinel?: No What is this outlet fed by?: Mains Supply pipe material: Copper Size of supply pipe: 15		
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)		Manually cleaned, descaled and disinfected
OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000025) Q / SCHOOL / GROUND FLOOR / CLEANERS BY YEAR 5 / SINK		
Type of Asset: Basin/Sink Is this outlet a sentinel?: No Is the outlet fed by a TMV?: No Is the outlet a mixer tap?: No Supply pipe material: Copper Size of supply pipe: 15		
Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)		Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000045)**Q / SCHOOL / GROUND FLOOR / DISABLED TOILET / BASIN**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 What is this outlet fed by?: Mains
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected



outlet

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000033)**Q / SCHOOL / GROUND FLOOR / DISABLED TOILET / BASIN**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 Is the outlet fed by a TMV?: No
 Is the outlet a mixer tap?: Yes
 Supply pipe material: Copper
 Size of supply pipe: 15
 General Comment: Hot & Cold water are opposite increasing the risk of scalding to vulnerable user Cold should be on the right hot should be on the left
 General Comment: Hot & Cold water are opposite increasing the risk of scalding to vulnerable user Cold should be on the right hot should be on the left

Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000055)**Q / SCHOOL / GROUND FLOOR / FOOD TECH / SINK FRONT**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 What is this outlet fed by?: Mains
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000027)**Q / SCHOOL / GROUND FLOOR / FOOD TECH / SINK FRONT**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 Is the outlet fed by a TMV?: Yes
 Is the outlet a mixer tap?: No
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000027)**Q / SCHOOL / GROUND FLOOR / FOOD TECH / SINK FRONT**

and cleaned)

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000056)**Q / SCHOOL / GROUND FLOOR / FOOD TECH / SINK REAR**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 What is this outlet fed by?: Mains
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected



outlet

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000021)**Q / SCHOOL / GROUND FLOOR / FOOD TECH / SINK REAR**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 Is the outlet fed by a TMV?: Yes
 Is the outlet a mixer tap?: No
 Supply pipe material: Copper
 Size of supply pipe: 15
 General Comment: TMV behind panel in LHS sink unit
 General Comment: TMV behind panel in LHS sink unit

Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (SENTINEL) (#CWOSEN_000024)**Q / SCHOOL / GROUND FLOOR / KITCHEN / BASIN**

Type of Asset: Basin/Sink/Domestic Bath
 Is this outlet a sentinel?: Yes
 Type of sentinel: Nearest Cold (NC)
 What is this outlet fed by?: Mains
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (SENTINEL) (#CWOSEN_000024)
Q / SCHOOL / GROUND FLOOR / KITCHEN / BASIN



outlet

OUTLET: HOT WATER (SENTINEL) (#HWOSEN_000022)
Q / SCHOOL / GROUND FLOOR / KITCHEN / BASIN

Type of Asset: Basin/Sink
Type of sentinel: Nearest Hot (NH)
Is this outlet a sentinel?: Yes
Is the outlet fed by a TMV?: No
Is the outlet a mixer tap?: No

Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000063)
Q / SCHOOL / GROUND FLOOR / KITCHEN / DOUBLE SINK / LHS

Type of Asset: Basin/Sink
Is this outlet a sentinel?: No
What is this outlet fed by?: Mains
Supply pipe material: Copper
Size of supply pipe: 15

Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000063)
Q / SCHOOL / GROUND FLOOR / KITCHEN / DOUBLE SINK / LHS



outlet

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000024)
Q / SCHOOL / GROUND FLOOR / KITCHEN / DOUBLE SINK / LHS

Type of Asset: Basin/Sink
Is this outlet a sentinel?: No
Is the outlet fed by a TMV?: No
Is the outlet a mixer tap?: Yes
Supply pipe material: Copper
Size of supply pipe: 15

Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000064)
Q / SCHOOL / GROUND FLOOR / KITCHEN / DOUBLE SINK / RHS

Type of Asset: Basin/Sink
Is this outlet a sentinel?: No
What is this outlet fed by?: Mains
Supply pipe material: Copper
Size of supply pipe: 15

Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000064)
Q / SCHOOL / GROUND FLOOR / KITCHEN / DOUBLE SINK / RHS



outlet

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000023)
Q / SCHOOL / GROUND FLOOR / KITCHEN / DOUBLE SINK / RHS

Type of Asset: Basin/Sink
Is this outlet a sentinel?: No
Is the outlet fed by a TMV?: No
Is the outlet a mixer tap?: Yes
Supply pipe material: Copper
Size of supply pipe: 15

Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000062)
Q / SCHOOL / GROUND FLOOR / KITCHEN / POT WASH SINK

Type of Asset: Basin/Sink
Is this outlet a sentinel?: No
What is this outlet fed by?: Mains
Supply pipe material: Copper
Size of supply pipe: 15

Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000062)
Q / SCHOOL / GROUND FLOOR / KITCHEN / POT WASH SINK



outlet

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000030)
Q / SCHOOL / GROUND FLOOR / KITCHEN / POT WASH SINK

Type of Asset: Basin/Sink
Is this outlet a sentinel?: No
Is the outlet fed by a TMV?: No
Is the outlet a mixer tap?: Yes
Supply pipe material: Copper
Size of supply pipe: 15

Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected



outlet

OUTLET: COLD WATER (#CWO_000027)
Q / SCHOOL / GROUND FLOOR / KITCHEN STAFF TOILET / BASIN

Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: HOT WATER (#HWO_000025) Q / SCHOOL / GROUND FLOOR / KITCHEN STAFF TOILET / BASIN	
Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected
OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000040) Q / SCHOOL / GROUND FLOOR / OUTSIDE RECEPTION CLASS	
Site Asset Number: Drinking Fountain Type of Asset: Basin/Sink Is this outlet a sentinel?: No What is this outlet fed by?: Mains Supply pipe material: Copper Size of supply pipe: 15	
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected
OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000050) Q / SCHOOL / GROUND FLOOR / OUTSIDE YEAR 2	
Site Asset Number: Bib Tap01 Type of Asset: Bib Tap Is this outlet a sentinel?: No What is this outlet fed by?: Mains Supply pipe material: Copper Size of supply pipe: 15	
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned and descaled
OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000057) Q / SCHOOL / GROUND FLOOR / OUTSIDE YEAR 3	
Site Asset Number: Drinking Fountain Type of Asset: Basin/Sink Is this outlet a sentinel?: No What is this outlet fed by?: Mains Supply pipe material: Copper Size of supply pipe: 15	
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned and descaled
OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000058) Q / SCHOOL / GROUND FLOOR / OUTSIDE YEAR 3	
Type of Asset: Bib Tap Is this outlet a sentinel?: No What is this outlet fed by?: Mains Supply pipe material: Copper Size of supply pipe: 15	
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned and descaled
OUTLET: COLD WATER (#CWO_000003) Q / SCHOOL / GROUND FLOOR / RECEPTION CLASS / DRINKING FOUNTAIN	
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (#CWO_000003)**Q / SCHOOL / GROUND FLOOR / RECEPTION CLASS / DRINKING FOUNTAIN**

outlet

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000061)**Q / SCHOOL / GROUND FLOOR / RECEPTION CLASS / LHS BASIN**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 What is this outlet fed by?: Mains
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected



outlet

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000045)**Q / SCHOOL / GROUND FLOOR / RECEPTION CLASS / LHS BASIN**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 Is the outlet fed by a TMV?: Yes
 Is the outlet a mixer tap?: No
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000065)**Q / SCHOOL / GROUND FLOOR / RECEPTION CLASS / RHS BASIN**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000065) Q / SCHOOL / GROUND FLOOR / RECEPTION CLASS / RHS BASIN	
What is this outlet fed by?: Mains Supply pipe material: Copper Size of supply pipe: 15	
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected
OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000044) Q / SCHOOL / GROUND FLOOR / RECEPTION CLASS / RHS BASIN	
Type of Asset: Basin/Sink Is this outlet a sentinel?: No Is the outlet fed by a TMV?: Yes Is the outlet a mixer tap?: No Supply pipe material: Copper Size of supply pipe: 15	
Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected
OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000060) Q / SCHOOL / GROUND FLOOR / STAFF LADIES TOILET / LHS BASIN	
Type of Asset: Basin/Sink Is this outlet a sentinel?: No What is this outlet fed by?: Mains Supply pipe material: Copper Size of supply pipe: 15	
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected
OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000031) Q / SCHOOL / GROUND FLOOR / STAFF LADIES TOILET / LHS BASIN	
Type of Asset: Basin/Sink Is this outlet a sentinel?: No Is the outlet fed by a TMV?: Yes Is the outlet a mixer tap?: No Supply pipe material: Copper Size of supply pipe: 15	
Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected
 outlet	
OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000059) Q / SCHOOL / GROUND FLOOR / STAFF LADIES TOILET / RHS BASIN	
Type of Asset: Basin/Sink Is this outlet a sentinel?: No What is this outlet fed by?: Mains Supply pipe material: Copper Size of supply pipe: 15	
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000032)**Q / SCHOOL / GROUND FLOOR / STAFF LADIES TOILET / RHS BASIN**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 Is the outlet fed by a TMV?: Yes
 Is the outlet a mixer tap?: No
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected




outlet

OUTLET: COLD WATER (#CWO_000028)**Q / SCHOOL / GROUND FLOOR / STAFF ROOM / SINK**

Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected



outlet

OUTLET: HOT WATER (#HWO_000026)**Q / SCHOOL / GROUND FLOOR / STAFF ROOM / SINK**

Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (#CWO_000006)**Q / SCHOOL / GROUND FLOOR / YEAR 1 CLASS / DRINKING FOUNTAIN**

Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (#CWO_000006)**Q / SCHOOL / GROUND FLOOR / YEAR 1 CLASS / DRINKING FOUNTAIN**

outlet

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000066)**Q / SCHOOL / GROUND FLOOR / YEAR 1 CLASS / LHS BASIN**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 What is this outlet fed by?: Mains
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000043)**Q / SCHOOL / GROUND FLOOR / YEAR 1 CLASS / LHS BASIN**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 Is the outlet fed by a TMV?: Yes
 Is the outlet a mixer tap?: No
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000067)**Q / SCHOOL / GROUND FLOOR / YEAR 1 CLASS / RHS BASIN**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 What is this outlet fed by?: Mains
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000042)**Q / SCHOOL / GROUND FLOOR / YEAR 1 CLASS / RHS BASIN**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 Is the outlet fed by a TMV?: Yes
 Is the outlet a mixer tap?: No
 Supply pipe material: Copper
 Size of supply pipe: 15

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000042) Q / SCHOOL / GROUND FLOOR / YEAR 1 CLASS / RHS BASIN	
Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected
OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000042) Q / SCHOOL / GROUND FLOOR / YEAR 2 CLASS / BASIN / LHS BASIN	
Type of Asset: Basin/Sink Is this outlet a sentinel?: No What is this outlet fed by?: Mains Supply pipe material: Copper Size of supply pipe: 15	
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected
OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000040) Q / SCHOOL / GROUND FLOOR / YEAR 2 CLASS / BASIN / LHS BASIN	
Type of Asset: Basin/Sink Is this outlet a sentinel?: No Is the outlet fed by a TMV?: Yes Is the outlet a mixer tap?: No Supply pipe material: Copper Size of supply pipe: 15	
Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected
OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000041) Q / SCHOOL / GROUND FLOOR / YEAR 2 CLASS / BASIN / RHS BASIN	
Type of Asset: Basin/Sink Is this outlet a sentinel?: No What is this outlet fed by?: Mains Supply pipe material: Copper Size of supply pipe: 15	
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected
OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000041) Q / SCHOOL / GROUND FLOOR / YEAR 2 CLASS / BASIN / RHS BASIN	
Type of Asset: Basin/Sink Is this outlet a sentinel?: No Is the outlet fed by a TMV?: Yes Is the outlet a mixer tap?: No Supply pipe material: Copper Size of supply pipe: 15	
Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected
OUTLET: COLD WATER (#CWO_000012) Q / SCHOOL / GROUND FLOOR / YEAR 3 CLASS / LHS BASIN	
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned and descaled
OUTLET: HOT WATER (SENTINEL) (#HWOSEN_000023) Q / SCHOOL / GROUND FLOOR / YEAR 3 CLASS / LHS BASIN	
Type of Asset: Basin/Sink Type of sentinel: Furthest Hot (FH) Is this outlet a sentinel?: Yes Is the outlet fed by a TMV?: Yes Is the outlet a mixer tap?: No	
Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned and descaled

OUTLET: COLD WATER (#CWO_000013) Q / SCHOOL / GROUND FLOOR / YEAR 3 CLASS / RHS BASIN		
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned and descaled	
OUTLET: HOT WATER (SENTINEL) (#HWOSEN_000024) Q / SCHOOL / GROUND FLOOR / YEAR 3 CLASS / RHS BASIN		
Type of Asset: Basin/Sink Type of sentinel: Furthest Hot (FH) Is this outlet a sentinel?: Yes Is the outlet fed by a TMV?: Yes Is the outlet a mixer tap?: No		
Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned and descaled	
OUTLET: COLD WATER (#CWO_000011) Q / SCHOOL / GROUND FLOOR / YEAR 3 CLASS / SINK		
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected	
 outlet		
OUTLET: HOT WATER (SENTINEL) (#HWOSEN_000025) Q / SCHOOL / GROUND FLOOR / YEAR 3 CLASS / SINK		
Type of Asset: Basin/Sink Type of sentinel: Furthest Hot (FH) Is this outlet a sentinel?: Yes Is the outlet fed by a TMV?: Yes Is the outlet a mixer tap?: No		
Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected	
OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000046) Q / SCHOOL / GROUND FLOOR / YEAR 4 BOYS TOILET / LHS		
Type of Asset: Basin/Sink Is this outlet a sentinel?: No What is this outlet fed by?: Mains Supply pipe material: Copper Size of supply pipe: 15		
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected	

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000046)**Q / SCHOOL / GROUND FLOOR / YEAR 4 BOYS TOILET / LHS**

outlet

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000034)**Q / SCHOOL / GROUND FLOOR / YEAR 4 BOYS TOILET / LHS**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 Is the outlet fed by a TMV?: Yes
 Is the outlet a mixer tap?: No
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000047)**Q / SCHOOL / GROUND FLOOR / YEAR 4 BOYS TOILET / RHS**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 What is this outlet fed by?: Mains
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000035)**Q / SCHOOL / GROUND FLOOR / YEAR 4 BOYS TOILET / RHS**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 Is the outlet fed by a TMV?: Yes
 Is the outlet a mixer tap?: No
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned and descaled



outlet

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000043)**Q / SCHOOL / GROUND FLOOR / YEAR 4 GIRLS TOILET / LHS**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 What is this outlet fed by?: Mains
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected



outlet

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000039)**Q / SCHOOL / GROUND FLOOR / YEAR 4 GIRLS TOILET / LHS**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 Is the outlet fed by a TMV?: Yes
 Is the outlet a mixer tap?: No
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected



outlet

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000044)**Q / SCHOOL / GROUND FLOOR / YEAR 4 GIRLS TOILET / RHS**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 What is this outlet fed by?: Mains
 Supply pipe material: Copper
 Size of supply pipe: 15

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000044) Q / SCHOOL / GROUND FLOOR / YEAR 4 GIRLS TOILET / RHS		
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected	
OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000038) Q / SCHOOL / GROUND FLOOR / YEAR 4 GIRLS TOILET / RHS		
Type of Asset: Basin/Sink Is this outlet a sentinel?: No Is the outlet fed by a TMV?: Yes Is the outlet a mixer tap?: No Supply pipe material: Copper Size of supply pipe: 15		
Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected	
OUTLET: COLD WATER (#CWO_000016) Q / SCHOOL / GROUND FLOOR / YEAR 5 CLASS / LHS BASIN		
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected	
OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000015) Q / SCHOOL / GROUND FLOOR / YEAR 5 CLASS / LHS BASIN		
Type of Asset: Basin/Sink Is this outlet a sentinel?: No Is the outlet fed by a TMV?: Yes Is the outlet a mixer tap?: No Supply pipe material: Copper Size of supply pipe: 15		
Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected	
OUTLET: COLD WATER (#CWO_000015) Q / SCHOOL / GROUND FLOOR / YEAR 5 CLASS / RHS BASIN		
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected	
OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000026) Q / SCHOOL / GROUND FLOOR / YEAR 5 CLASS / RHS BASIN		
Type of Asset: Basin/Sink Is this outlet a sentinel?: No Is the outlet fed by a TMV?: Yes Is the outlet a mixer tap?: No Supply pipe material: Copper Size of supply pipe: 15		
Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected	
OUTLET: COLD WATER (#CWO_000017) Q / SCHOOL / GROUND FLOOR / YEAR 5 CLASS / SINK		
Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)	Manually cleaned, descaled and disinfected	

OUTLET: COLD WATER (#CWO_000017)**Q / SCHOOL / GROUND FLOOR / YEAR 5 CLASS / SINK**

outlet

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000028)**Q / SCHOOL / GROUND FLOOR / YEAR 5 CLASS / SINK**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 Is the outlet fed by a TMV?: Yes
 Is the outlet a mixer tap?: No
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000054)**Q / SCHOOL / GROUND FLOOR / YEAR 6 CLASS / LHS BASIN**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 What is this outlet fed by?: Mains
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000047)**Q / SCHOOL / GROUND FLOOR / YEAR 6 CLASS / LHS BASIN**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 Is the outlet fed by a TMV?: Yes
 Is the outlet a mixer tap?: No
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000053)**Q / SCHOOL / GROUND FLOOR / YEAR 6 CLASS / RHS BASIN**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 What is this outlet fed by?: Mains
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000046)**Q / SCHOOL / GROUND FLOOR / YEAR 6 CLASS / RHS BASIN**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 Is the outlet fed by a TMV?: Yes
 Is the outlet a mixer tap?: No
 Supply pipe material: Copper

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000046)**Q / SCHOOL / GROUND FLOOR / YEAR 6 CLASS / RHS BASIN**

Size of supply pipe: 15

Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected

OUTLET: COLD WATER (NON-SENTINEL) (#CWONS_000052)**Q / SCHOOL / GROUND FLOOR / YEAR 6 CLASS / SINK**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 What is this outlet fed by?: Mains
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically cleaned / descaled the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected



outlet

OUTLET: HOT WATER (NON-SENTINEL) (#HWONS_000029)**Q / SCHOOL / GROUND FLOOR / YEAR 6 CLASS / SINK**

Type of Asset: Basin/Sink
 Is this outlet a sentinel?: No
 Is the outlet fed by a TMV?: Yes
 Is the outlet a mixer tap?: No
 Supply pipe material: Copper
 Size of supply pipe: 15

Manually and chemically clean / descale the outlet. (Diffusers that are fitted will be removed and cleaned)

Manually cleaned, descaled and disinfected