

Nutfield Church Primary School Mid Street South Nutfield REDHILL RH1 4JJ	Operational rating B	Certificate number: 2845-1869-8144-3802-8991
		Valid until: 16 January 2025
		Total useful floor area: 1,474.3 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO2) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B	44 B	
51-75	C		
76-100	D		
		100	
101-125	E		
126-150	F		
150+	G		

This building's energy use		
Energy use	Electricity	Other fuels
Annual energy use (kWh/m2/year)	21.63	51.16
Typical energy use (kWh/m2/year)	40	142.37
Energy from renewables	0%	0%

Previous operational ratings	
Date	Operational rating
January 2024	44 B
January 2023	46 B
January 2022	59 C

Total carbon dioxide (CO2) emissions			
This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO2.			
Date	Electricity	Heating	Renewables
January 2024	18	15	0
January 2023	17	17	0
January 2022	22	20	0

Assessment details	
Assessor's name	Keifer Ballard
Employer/Trading name	Compliance 365
Employer/Trading address	6 Mariner Ct, Durkar, Wakefield WF4 3FL
Assessor's declaration	Not related to the occupier.
Accreditation scheme	Elmhurst Energy Systems Ltd
Issue date	18 January 2024
Nominated date	17 January 2024

