

## Maintenance Certificate

Name Nutfield Church Primary School  
Address 59 Mid Street  
South Nutfield  
Surrey

Postcode RH1 4JJ

Job Ref: 445208  
Engineer Clive Hearn

Arrived 01/08/23 08:45  
Left 01/08/23 10:10

Our Ref: NUTFIE::  
Installation: A) Intruder Alarm System  
Premises: C) Public Sector  
Signalling: E) BT RedCARE  
Order No:  
Reason for Visit: Routine Maintenance Visit  
Call Out Charge 0.00  
Materials 36.00  
Other 0.00  
Total Ex VAT: 36.00

Parts + Materials Used: 1.00 Yuasa 7Ah Battery

### Findings and Action Taken:

Rm Routine Maintenance: all checks completed all ok. Replaced battery in psu 2.

### Outstanding company action:

[25/05/18] [10/02/15]  
[10/02/15] [27/02/15] [21/05/15]

[10/02/15] [27/02/15][10/02/15]

[There were no disconnections on this visit.](#)

[There were no isolations on this visit.](#)

Checks carried out:

1 Check the installation, location and siting of all equipment against the specification and is fitted to the relevant standards stated on the specification

2 Check the satisfactory operation of all detection devices

3 Check the satisfactory operation of all deliberately operated devices

4 Check that the battery requirements meet the fitted regulation as stated on the specification

5 Check mains and standby power supplies including correct charging and standby rates

6 Check control unit for correct operation

7 Check remote signalling equipment (intelligibility to be ascertained)

8 Test signalling equipment to central station

9 Setting procedure tested where possible along with any part sets

10 Engineer's copy of specification and or drawings marked up and left in control panel (where appropriate). Copies to be sent to office

11 Check operation of all audible warning devices for correct operation

12 Check alarm system is fully operational

13 Panel Voltage  
13.86

14 Panel mA  
435

15 PSU Voltage 1  
13.79

16 PSU mA 1  
300

17 PSU Voltage 2  
14.02

18 PSU mA 2  
174

19 PSU Voltage 3  
13.88

20 PSU mA 3  
192

21 PSU Voltage 4

22 PSU mA 4

23 PSU Voltage 5

24 PSU mA 5

25 PSU Voltage 6

26 PSU mA 6

27 PSU Voltage 7

28 PSU mA 7

29 PSU Voltage 8

30 PSU mA 8

31 PSU Voltage 9

32 PSU mA 9

Signed by client:

*Clive Hearn*

*[Signature]*

Carried out by: Clive Hearn

Alfred at 01/08/23 10:10

Visit us at:  
[admiralsecurity.co.uk](http://admiralsecurity.co.uk)

info@admiralsecurity.co.uk  
01737 855 900 (Surrey) / 01444 440 184 (Sussex)

Trading address: Office F3, Robert Denholm House, Bletchingley Road, South Nutfield, Surrey, RH1 4HW

Registered address: 2, Effingham Road, Reigate, Surrey, RH2 7JN

Registered in England & Wales No. 2722048. VAT No. 602 4307 88

Directors: Andrew Austin, Phillip Burchell, Andrew Gerrard

