

ANNUAL FIRE EXTINGUISHER REPORT / CERTIFICATE

RJ Fire

Fire & Security Specialists

32 Cinnabar Drive
Sittingbourne
Kent ME10 5LA

CLIENT
NUTFIELD C/E SCHOOL
59 MID STREET
SOUTH NUTFIELD
RH1 4JJ

CERTIFICATE NO: **EX7246**

WORKS REF NO:

INSPECTION DATE:	SERVICE INSPECTIONS AT:	SERVICE INSPECTIONS:	NEXT SERVICE:
15/08/2023	NUTFIELD C/E SCHOOL 59 MID STREET RH1 4JJ	ANNUAL	AUGUST 2024

DISCIPLINES:	ANNUAL SERVICE & MAINTENANCE CARRIED OUT TO: BS 5306 PART 3 & REFILLED WHEN REQUIRED TO BS 6643 PART 1		
FIRE FIGHTING EQUIPMENT:		PASS	TEST DUE/FAIL
6LT WATER	4	4	
9LT WATER			
2LT FOAM			
6LT FOAM	4	3	1
9LT FOAM			
2KG CO2	7	6	1
5KG CO2			
1KG POWDER			
4KG POWDER	2		
6KG POWDER			
6LT WET CHEM			
FIRE BLANKETS	13	13	
CO2 HORN			
NEW UNITS REQUIRED	2		
NITROGEN CHARGE			
TOTAL UNITS SERVICED	30		

SERVICE ENGINEER:

R.Jones

X 1 6LT H2O REQUIRED
X 1 6LT AFFF FOAM REQUIRED