

Nutfield Church (C of E) Primary School



Record of Fire Drills and Instruction

Date and Time of Drill	Persons attending, time taken to evacuate and other considerations	Signed
Tuesday 1st October 2024 at 01:20	Alarm sounded at 01:20. The premises was empty at the time of the alarm. FK heard the alarm at around 02:20 am and attended the school to investigate. FK checked the fire alarm panel to seek the source of the fire/activation. The panel showed errors on 3 sensors detector as the source Investigation indicated there was no obvious reason for the alarm to have been activated and no smell of smoke. FK carried out checks of the area to confirm that the building was empty. FK silenced the alarm and reset. Staff, students and visitors returned to the building at 09:37 FK left the building at 02:28am	Imogen Woods