



This certificate is not valid if the serial number has been defaced or altered

30961087

EICR18.3C

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

DETAILS OF THE CONTRACTOR		DETAILS OF THE CLIENT		DETAILS OF THE INSTALLATION	
Registration No: 019933000 Branch No*: 000		Contractor Reference Number (CRN): N/A		Occupier: Nutfield C of E Primary School - Caretakers House 158855.00	
Trading Title: Quantec Consultants Ltd		Name: Surrey CC on behalf of Corrigenda		UPRN: N/A	
Address: Unit 1, Oaks Business Village, Chatham, Kent		Address: Surrey County Council, Woodhatch, Cockshot Hill, Reigate, Surrey		Address: Mid Street South, Nutfield, Redhill, Surrey	
Postcode: ME5 8LF Tel No: 01634865750		Postcode: RH2 8BF Tel No: N/A		Postcode: RH1 4JJ Tel No: N/A	

PART 2 : PURPOSE OF THE REPORT

Purpose for which this report is required:
To meet the requirements of BS7671: 2018 & A2 2022 and our clients electrical testing regime.

Date(s) when inspection and testing was carried out: (16/01/2025) Records available (651.1): (N/A) Previous inspection report available (651.1): (N/A) Previous report date: (N/A)

PART 3 : SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety): Refer to Quantec Report No. F/4234-17B

Description of premises Dwelling: (✓) Commercial: (N/A) Industrial: (N/A) Other (include brief description): (N/A)

Estimated age of electrical installation: (25) years Evidence of additions or alterations: (✓) if Yes, estimated age 10 years Overall assessment of the installation for continued use: Satisfactory/Unsatisfactory** (delete as appropriate)

**An unsatisfactory assessment indicates that dangerous (Code C1) and/or potentially dangerous (Code C2) conditions have been identified (listed in PART 5 of this report) and it is recommended that these are acted upon as a matter of urgency.

PART 4 : DECLARATION

INSPECTION AND TESTING

I/We, being the person responsible for the inspection and testing of the electrical installation (as indicated by my/our signature below), particulars of which are described in PART 6, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations (PART 5) and the attached Schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in PART 6 of this report.

Name (capitals) on behalf of the contractor identified in PART 1: JOSH PAINTER Signature: [Signature] Date: 22/01/2025

I/We further RECOMMEND, subject to the necessary remedial action being taken, that the installation is inspected and tested by: 16/01/2030 (date)

Give reason for recommendation: In line with industry standard.

The proposed date for the next inspection should take into consideration any legislative or licensing requirements and the frequency and quality of maintenance that the installation can reasonably be expected to receive during its intended life. The period should be agreed between relevant parties.

REVIEWED BY THE REGISTERED QUALIFIED SUPERVISOR FOR THE CONTRACTOR

Name (capitals) on behalf of the contractor identified in PART 1: IAN KEATING Signature: [Signature] Date: 22/01/2025

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART 5 : OBSERVATIONS

One of the following Codes, as appropriate, has been allocated to each of the observations made below to indicate to the person(s) responsible for the electrical installation the degree of urgency for remedial action:

Code C1 Danger Present
Risk of injury. Immediate remedial action required

Code C2 Potentially Dangerous
Urgent remedial action required

Code C3
Improvement Recommended

Code FI
Further Investigation Required

Referring to the **Schedule of Items Inspected** (see PART 9), the attached **Schedule of Circuit Details and Test Results** (see PART 11A & 11B), and subject to any **agreed limitations** listed in PART 6 –

No remedial action is required (☒), OR The following observations are made:

Item No	Observation(s)	Code	Location Reference
(1)	(5.1 See Report)	(C3)	()
(2)	(5.15 See Report)	(C3)	()
(3)	(6.1 See Report)	(C3)	()
(4)	(6.14 See Report)	(C3)	()
(5)	(Gas installation pipes)	(C3)	()
(6)	(Water installation pipes)	(C3)	()
()	()	()	()
()	()	()	()
()	()	()	()
()	()	()	()
()	()	()	()
()	()	()	()
()	()	()	()
()	()	()	()
()	()	()	()
()	()	()	()
()	()	()	()
()	()	()	()
()	()	()	()
()	()	()	()
()	()	()	()
()	()	()	()
()	()	()	()

Additional pages? (None) State page numbers: (N/A)

Immediate remedial action required for items: (N/A)

Improvement recommended for items: (1,2,3,4,5,6)

Urgent remedial action required for items: (N/A)

Further investigation required for items: (N/A)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART 6 : DETAILS AND LIMITATIONS OF THE INSPECTION AND TESTING

The inspection and testing has been carried out in accordance with BS 7671: 2018, as amended to ...2022... (date). Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the Client and the Inspector prior to inspection.

Details of the electrical installation covered by this report: Completed in accordance with client's specification/Quantec Consultants scope and limitations of testing. (see additional page No. N/A.)

Agreed limitations including the reasons, if any, on the inspection and testing (653.2): Please refer to limitations within Quantec Report No. F/4234-17B

Agreed with (print name): N/A

Extent of sampling: As detailed in Sections 7-10 of Quantec Report No. F/4234-17B (see additional page No. N/A.)

Operational limitations including the reasons: N/A (see additional page No. N/A.)

PART 7 : SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System type and earthing arrangements			Number and type of live conductors		Nature of supply parameters	
TN-C: (<u>N/A</u>)	TN-S: (<u>N/A</u>)	TN-C-S: (<u>✓</u>)	AC 1-phase, 2-wire: (<u>✓</u>)	2-phase, 3-wire: (<u>N/A</u>)	Nominal voltage between lines, U [1]:	(<u>N/A</u>) V
TT: (<u>N/A</u>)	IT: (<u>N/A</u>)		3-phase, 3-wire: (<u>N/A</u>)	3-phase, 4-wire: (<u>N/A</u>)	Nominal line voltage to Earth, U_0 [1]:	(<u>230</u>) V
Supply protective device			DC 2-wire: (<u>N/A</u>)	3-wire: (<u>N/A</u>)	Nominal frequency, f [1]:	(<u>50</u>) Hz
BS EN: (<u>1361</u>)	Type: (<u>I</u>)	Rated current: (<u>100</u>) A	Confirmation of supply polarity: (<u>✓</u>)	Other: (<u>N/A</u>)	Prospective fault current, I_{pf} [2]*:	(<u>N/A</u>) kA
			Other sources of supply (Schedule of Test Results)	Page No: (<u>N/A</u>)	External earth fault loop impedance, Z_e [2]*:	(<u>0.13</u>) Ω

[1] By enquiry

[2] By enquiry or by measurement

PART 8 : PARTICULARS OF INSTALLATION REFERRED TO IN THIS REPORT

Maximum demand (load): (<u>100</u>) W /A (delete as appropriate)	Main protective conductors		Main protective bonding connections		Main switch / Switch-fuse / Circuit-breaker / RCD	
Means of Earthing	Earthing conductor:		Water installation pipes: (<u>✓</u>)		Location: (<u>Main Intake Position in Garage</u>)	
Distributor's facility: (<u>✓</u>)	(material <u>Copper</u>)		Gas installation pipes: (<u>✓</u>)		BS EN: (<u>60947-3</u>)	
Installation earth electrode(s): (<u>N/A</u>)	csa (<u>25</u>) mm ² Connection/continuity verified: (<u>✓</u>)		Structural steel: (<u>N/A</u>)		Type: (<u>3</u>)	
Earth electrode type – rod(s), tape, etc: (<u>None</u>)	Main protective bonding conductors:		Oil installation pipes: (<u>N/A</u>)		Rating / setting of device: (<u>100</u>) A	
Location: (<u>N/A</u>)	(material <u>Copper</u>)		Lightning protection: (<u>N/A</u>)		No. of poles: (<u>2</u>)	
Electrode resistance to Earth: (<u>N/A</u>) Ω	csa (<u>16</u>) mm ² Connection/continuity verified: (<u>✓</u>)		Other (state): (<u>N/A</u>)		Current rating: (<u>100</u>) A	
			(<u>N/A</u>)		Voltage rating: (<u>230</u>) V	
			(<u>N/A</u>)		Where an RCD is used as the main switch	
			(<u>N/A</u>)		RCD rated residual operating current, $I_{\Delta n}$: (<u>N/A</u>) mA	
			(<u>N/A</u>)		RCD Type: (<u>N/A</u>)	
			(<u>N/A</u>)		Rated time delay: (<u>N/A</u>) ms	
			(<u>N/A</u>)		Measured operating time: (<u>N/A</u>) ms	

*Where the installation is supplied by more than one source, the higher or highest values of prospective fault current, I_{pf} , and external earth fault loop impedance, Z_e , must be recorded.

All fields must be completed. Enter either, as appropriate: '✓' if Acceptable condition; 'N/A' if Not applicable; 'LIM' if a Limitation exists, or Code appropriately: CODE 'C1', 'C2', 'C3' or 'F1' (codes to be recorded in PART 5, with additional comments (where appropriate) on attached numbered sheets)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART 9 : SCHEDULE OF ITEMS INSPECTED (enter ✓, N/A or Classification Code C1, C2, C3 or FI, as applicable)

1.0 Intake equipment (visual inspection only)

An outcome against an item in section 1.1, other than access to live parts, should not be used to determine the overall assessment of the installation. Where inadequacies are identified, a cross should be put against the appropriate item and a comment made in Part 5 of this report.

1.1 Distributor / supplier intake equipment

- Service cable (.....✓.....)
- Service head (.....✓.....)
- Earthing arrangement (.....✓.....)
- Meter tails (.....✓.....)
- Metering equipment (.....✓.....)
- Isolator, where present (N/A.....)

Where inadequacies in the intake equipment are encountered, which may result in a dangerous or potentially dangerous situation, the person ordering the work and / or dutyholder must be informed. It is strongly recommended that the person ordering the work informs the appropriate authority.

- 1.2 Consumer's isolator, where present (N/A.....)
- 1.3 Consumer's meter tails (N/A.....)

2.0 Presence of adequate arrangements for parallel or switched alternative sources

- 2.1 Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6) (N/A.....)
- 2.2 Adequate arrangements where a generating set operates in parallel with the public supply (551.7) (N/A.....)

3.0 Methods of protection

3.1 Automatic disconnection of supply (ADS)

- Main earthing / bonding arrangement (411.3; Chap. 54) (.....✓.....)
- Presence of distributor's earthing arrangement (542.1.2.1; 542.1.2.2), or presence of installation earth electrode arrangement (542.1.2.3) (.....✓.....)
- Adequacy of earthing conductor size (542.3; 543.1.1) (.....✓.....)
- Adequacy of earthing conductor connections (542.3.2) (.....✓.....)
- Accessibility of earthing conductor connections (543.3.2) (.....✓.....)
- Adequacy of main protective bonding conductor sizes (544.1.1) (.....✓.....)
- Adequacy and location of main protective bonding conductor connections (544.1.2) (C3.....)

- Accessibility of all protective bonding connections (543.3.2) (.....✓.....)
- Provision of earthing / bonding labels at all appropriate locations (514.13.1) (.....✓.....)

3.2 FELV - requirements satisfied (411.7) (.....✓.....)

3.3 Other methods of protection

Where any of the methods listed below are employed, details should be provided on separate sheets

- Non-conducting location (418.1) (N/A.....)
- Earth-free local equipotential bonding (418.2) (N/A.....)
- Electrical separation (413; 418.3) (N/A.....)
- Double insulation (412) (N/A.....)
- Reinforced insulation (412) (N/A.....)
- Provisions where automatic disconnection of supply is not feasible (419) (N/A.....)

4.0 Distribution equipment, including consumer units and distribution boards

- 4.1 Adequacy of working space / accessibility to equipment (132.12; 513.1) (.....✓.....)
- 4.2 Security of fixing (134.1.1) (.....✓.....)
- 4.3 Condition of insulation of live parts (416.1) (.....✓.....)
- 4.4 Adequacy security of barriers or enclosures (416.2.3) (.....✓.....)
- 4.5 Condition of enclosure(s) in terms of IP rating, etc. (416.2) (.....✓.....)
- 4.6 Condition of enclosure(s) in terms of fire rating, etc. (421.1.201; 421.1.6; 526.5) (.....✓.....)
- 4.7 Enclosure not damaged / deteriorated so as to impair safety (651.2) (.....✓.....)
- 4.8 Presence and effectiveness of obstacles (417.2) (.....✓.....)
- 4.9 Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2) (.....✓.....)
- 4.10 Operation of main switch(es) (functional check) (643.10) (.....✓.....)
- 4.11 Manual operation of circuit-breakers, RCDs and AFDDs to prove functionality (643.10) (.....✓.....)
- 4.12 Confirmation that integral test button / switch causes RCD(s) to trip when operated (functional check) (643.10) (.....✓.....)
- 4.13 RCD(s) provided for fault protection - includes RCBOs (411.4.204; 411.4.5; 411.5.2; 531.2) (.....✓.....)
- 4.14 RCD(s) provided for additional protection / requirements, where required - includes RCBOs (411.3.3; 415.1) (.....✓.....)
- 4.15 Presence of RCD six-monthly test notice, where required (514.12.2) (.....✓.....)

- 4.16 Confirmation that integral test button / switch, where present, causes AFDD to trip when operated (643.10) (N/A.....)
- 4.17 Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1) (.....✓.....)
- 4.18 Presence of alternative supply warning notice at or near equipment, where required (514.15) (.....✓.....)
- 4.19 Presence of next inspection recommendation label, where required (514.12.1) (.....✓.....)
- 4.20 Presence of other required labelling (please specify) (514) (.....✓.....)
- 4.21 Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (432; 433; 434) (.....✓.....)
- 4.22 Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3) (.....✓.....)
- 4.23 Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11) (.....✓.....)
- 4.24 Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1) (.....✓.....)
- 4.25 Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1) (.....✓.....)

5.0 Distribution circuits

- 5.1 Identification of conductors (514.3) (C3.....)
- 5.2 Cables correctly supported throughout their run (521.10.202; 522.8.5) (.....✓.....)
- 5.3 Condition of insulation of live parts (416.1) (.....✓.....)
- 5.4 Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1) (.....✓.....)
- 5.5 Suitability of containment systems for continued use (including flexible conduit) (522) (.....✓.....)
- 5.6 Cables correctly terminated in enclosures (526) (.....✓.....)
- 5.7 Examination of cables for signs of unacceptable thermal or mechanical damage / deterioration (421.1; 522.6) (.....✓.....)
- 5.8 Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (523) (.....✓.....)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART 9 : SCHEDULE OF ITEMS INSPECTED (enter ✓, N/A or Classification Code C1, C2, C3 or FI, as applicable)

5.9	Adequacy of protective devices; type and rated current for fault protection (411.3)	(.....✓.....)	6.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	(.....✓.....)	▪ *For cables concealed in walls / partitions containing metal parts regardless of depth (522.6.203)	(.....✓.....)	
5.10	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	(.....✓.....)	6.3	Condition of insulation of live parts (416.1)	(.....✓.....)	▪ *For final circuits supplying luminaires within domestic (household) premises (411.3.4)	(.....✓.....)	
5.11	Coordination between conductors and overload protective devices (433.1; 533.2.1)	(.....✓.....)	6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)	(.....✓.....)			
5.12	Cable installation methods / practices with regard to the type and nature of installation and external influences (522)	(.....✓.....)	6.5	Suitability of containment systems for continued use (including flexible conduit) (522)	(.....✓.....)	* Older installations designed prior to BS 7671: 2018 may not have required RCDs for additional protection.		
5.13	Where exposed to direct sunlight, cable of a suitable type (522.11.1)	(.....✓.....)	6.6	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation (523)	(.....✓.....)	6.14	Provision of fire barriers, sealing arrangements and protection against thermal effects (527)	C3 (.....✓.....)
5.14	Cables concealed under floors, above ceilings, in walls / partitions, adequately protected against damage (522.6.201; 522.6.202; 522.6.203; 522.6.204) –		6.7	Adequacy of protective devices; type and rated current for fault protection (411.3)	(.....✓.....)	6.15	Band II cables segregated / separated from Band I cables (528.1)	(.....✓.....)
▪ Installed in prescribed zones (see Section D. <i>Extent and limitations</i>) (522.6.202)	(.....✓.....)		6.8	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	(.....✓.....)	6.16	Cables segregated / separated from non-electrical services (528.3)	(.....✓.....)
▪ Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D) (522.6.201; 522.6.204)	(.....✓.....)		6.9	Co-ordination between conductors and overload protective devices (433.1; 533.2.1)	(.....✓.....)	6.17	Termination of cables at enclosures - identify / record numbers and locations of items inspected (526) –	
5.15	Provision of fire barriers, sealing arrangements and protection against thermal effects (527)	C3 (.....✓.....)	6.10	Wiring system(s) appropriate for the type and nature of the installation and external influences (522)	(.....✓.....)	▪ Connection under no undue strain (526.6)	(.....✓.....)	
5.16	Band II cables segregated / separated from Band I cables (528.1)	(.....✓.....)	6.11	Where exposed to direct sunlight, cable of a suitable type (522.11.1)	(.....✓.....)	▪ No basic insulation of a conductor visible outside enclosure (526.8)	(.....✓.....)	
5.17	Cables segregated / separated from non-electrical services (528.3)	(.....✓.....)	6.12	Cables concealed under floors, above ceilings, in walls / partitions, adequately protected against damage (522.6.201; 522.6.202; 522.6.203; 522.6.204) –		▪ Connections of live conductors adequately enclosed (526.5)	(.....✓.....)	
5.18	Condition of circuit accessories (651.2)	(.....✓.....)	▪ Installed in prescribed zones (see Section D. <i>Extent and limitations</i>) (522.6.202)	(.....✓.....)		▪ Adequately connected at point of entry to enclosure (glands, bushes, etc.) (522.8.5)	(.....✓.....)	
5.19	Suitability of circuit accessories for external influences (512.2)	(.....✓.....)	▪ Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D) (522.6.201; 522.6.204)	(.....✓.....)		6.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2)	(.....✓.....)
5.20	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	(.....✓.....)				6.19	Suitability of accessories for external influences (512.2)	(.....✓.....)
5.21	Adequacy of connections, including cpcs, within accessories and to fixed and stationary equipment - identify / record numbers and locations of items inspected (526)	(.....✓.....)	6.13	Provision of additional protection by RCD having rated residual operating current not exceeding 30 mA –		6.20	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	(.....✓.....)
5.22	Presence, operation and correct location of appropriate devices for isolation and switching (Chap. 46; 537)	(.....✓.....)	▪ *For all socket-outlets of rating 32 A or less (411.3.3)	(.....✓.....)		7.0 Isolation and switching		
5.23	General condition of wiring system (651.2)	(.....✓.....)	Additional protection by RCD may not have been provided as a noted exception in certain non-domestic installations covered by indent (ii) of Regulation 411.3.3.			7.1	Isolators –	
5.24	Temperature rating of cable insulation (522.11; Table 52.1)	(.....✓.....)	▪ *For the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	(.....✓.....)		▪ Presence and condition of appropriate devices (462; 537.2)	(.....✓.....)	
6.0 Final circuits			▪ *For cables concealed in walls at a depth of less than 50 mm (522.6.202)	(.....✓.....)		▪ Acceptable location - state if local or remote from equipment in question (462; 537.2.7)	(.....✓.....)	
6.1	Identification of conductors (514.3)	C3 (.....✓.....)				▪ Capable of being secured in the OFF position (462.3)	(.....✓.....)	
						▪ Correct operation verified (643.10)	(.....✓.....)	
						▪ Clearly identified by position and / or durable marking (537.2.7)	(.....✓.....)	
						▪ Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2)	(.....✓.....)	

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART 9 : SCHEDULE OF ITEMS INSPECTED (enter ✓, N/A or Classification Code C1, C2, C3 or FI, as applicable)

7.2 Switching off for mechanical maintenance –		8.5 Security of fixing (134.1.1)	(.....✓.....)	▪ Low voltage (e.g. 230 volt) socket-outlets sited at least 2.5 m from zone 1 (701.512.3)	(.....✓.....)
▪ Presence and condition of appropriate devices (464.1; 537.3.2)	(N/A.....)	8.6 Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: list number and location of luminaires inspected (separate page) (527.2)	(.....✓.....)	▪ Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)	(.....✓.....)
▪ Capable of being secured in the OFF position where not under continuous supervision (464.2)	(N/A.....)	8.7 Recessed luminaires (downlighters) –		▪ Suitability of accessories and controlgear etc. for a particular zone (701.512.3)	(.....✓.....)
▪ Correct operation verified (643.10)	(N/A.....)	▪ Correct type of lamps fitted (559.3.1)	(.....✓.....)	▪ Suitability of current-using equipment for particular position within the location (701.55)	(.....✓.....)
▪ Clearly identified by position and / or durable marking (537.3.2.4)	(N/A.....)	▪ Installed to minimise build-up of heat by use of “fire rated” fittings, insulation displacement box or similar (421.1.2)	(.....✓.....)	9.2 Other special installations or locations –	
7.3 Emergency switching off –		▪ No signs of overheating to surrounding building fabric (559.4.1)	(.....✓.....)	N/A	(N/A.....)
▪ Presence and condition of appropriate devices (465; 537.3.3; 537.4)	(.....✓.....)	▪ No signs of overheating to conductors / terminations (526.1)	(.....✓.....)		(.....)
▪ Readily accessible for operation where danger might occur (537.3.3.6)	(.....✓.....)				(.....)
▪ Correct operation verified (643.10)	(.....✓.....)				(.....)
▪ Clearly identified by position and / or durable marking (537.3.3.5; 537.3.3.6; 537.4.3; 537.4.4)	(.....✓.....)				(.....)
7.4 Functional switching –					(.....)
▪ Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2)	(N/A.....)				(.....)
▪ Correct operation verified (643.10)	(N/A.....)				(.....)
8.0 Current-using equipment (permanently connected)		9.0 Special locations and installations		10.0 Prosumer's low voltage installation	(N/A.....)
8.1 Condition of equipment in terms of IP rating, etc. (416.2; 422.3; 422.4; 522.4)	(.....✓.....)	Where special installations or locations relating to a particular Section of Part 7, an additional Inspection Schedule(s) should be provided on separate pages.		Where elements of a prosuming installation falling within the scope of Chapter 82 are covered by the report, additional schedules detailing the associated inspection and testing should be provided on separate pages.	
8.2 Equipment does not constitute a fire hazard (421)	(.....✓.....)	9.1 Location(s) containing a bath or shower –		Schedule of Items Inspected by	
8.3 Enclosure not damaged / deteriorated so as to impair safety (134.1.1; 416.2)	(.....✓.....)	▪ Additional protection by RCD having rated residual operating current not exceeding 30 mA for all low voltage (LV) circuits serving the location or passing through zones 1 and / or 2 of the location (701.411.3.3)	(.....✓.....)	Name (capitals): JOSH PAINTER	
8.4 Suitability for the environment and external influences (512.2)	(.....✓.....)	▪ Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)	(N/A.....)	Signature:  Date: 22/01/2025	
		▪ Shaver supply units complying with BS EN 61558-2-5 formerly BS 3535 (701.512.3)	(N/A.....)		
		▪ Presence of supplementary bonding conductors, unless not required by BS 7671: 2018 (701.415.2)	(N/A.....)		

PART 10 : SCHEDULES AND ADDITIONAL PAGES (the pages identified are an essential part of this report (see Regulation 653.2))

Schedule of Inspections	Schedule of Circuit Details and Test Results for the installation	Additional pages, including data sheets for additional sources	Special installations or locations (indicated in item 9.2 above)	Schedules relating to Prosumer's installations (indicated in item 10 above)	Continuation sheets
Page No(s): (.....4, 5 & 6.....)	Page No(s): (.....7 & 8.....)	Page No(s): (None.....)	Page No(s): (None.....)	Page No(s): (None.....)	Page No(s): (None.....)



This certificate is not valid if the serial number has been defaced or altered

30961087

EICR18.3C

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with *BS 7671: 2018* (as amended) – Requirements for Electrical Installations

PART 11A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part 11B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

[illegible]

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation: N/A

Location of DB: N/A

$$Z_{dbt}: \text{N/A} \quad \dots \quad (\Omega) \qquad I_{p\text{fat DBT}}: \text{N/A} \quad \dots \quad (\text{kA})$$

Confirmation of supply polarity: (N/A) Phase sequence confirmed†: (N/A)

SPD Details** Types: T1 (N/A) , T2 (N/A) , T3 (N/A) , N/A (N/A)

Status indicator checked (where functionality indicator is present): (N/A)

**SPD Type.

Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.

Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART 11B),

(See Section 534 for further details).
Note that not all SPDs have visible
functionality indication.

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: N/A

Overcurrent protective device for the distribution circuit

BS (EN): (N/A) Type: (N/A) Nominal voltage: (N/A) V Rating: (N/A) A No. of phases: (N/A)

Associated RCD (if any)

BS (EN): (N/A) RCD Type: (N/A) $I_{\Delta n}$: (N/A) mA No. of poles: (N/A) Operating time: (N/A) ms

This report is based on the model forms shown in Appendix 6 of BS 7671: 2018 (as amended)
@ Copyright Certsure LLP (August 2024)

Enter a (✓) or value in the respective fields, as appropriate. Where an item is not applicable insert N/A

† Where applicable. *Where figure is not taken from BS 7671, state source: N/A Page 7 of 8

Original (to the person ordering the work)



This certificate is not valid if the serial number has been defaced or altered

30961087

EICR18.3C

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with *BS 7671: 2018* (as amended) – Requirements for Electrical Installations

PART 11B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part 11A)

[illegible]

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

TESTED BY Name (capital): JOSH PAINTER Position: Engineer Signature: [Signature] Date: 22/01/2025

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function:	Continuity:	Insulation resistance:	Earth fault loop impedance:	Earth electrode resistance:	RCD:
N/A	N/A	N/A	N/A	N/A	N/A

* RCD effectiveness is verified using an alternating current test at rated residual operating current ($I_{\Delta n}$)

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state) <u>N/A</u>
---------------------------------	--	---	---	--	--	---------------------------------------	---------------------------------------	-------------------------------------	--------------------------

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018 (as amended)
 @ Copyright Certsure LLP (August 2024)

Enter a (✓), (X) or value in the respective fields, as appropriate
Where an item is not applicable insert N/A

Original (to the person ordering the work)

NOTES FOR RECIPIENT

THIS CONDITION REPORT IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE USE

The purpose of periodic inspection is to determine, so far as is reasonably practicable, whether an electrical installation is in a satisfactory condition for continued service. This report provides an assessment of the condition of the electrical installation identified overleaf at the time it was inspected and tested, taking into account the stated extent of the installation and the limitations of the inspection and testing.

This report has been issued in accordance with the national standard for the safety of electrical installations, *BS 7671: 2018* (as amended) – Requirements for Electrical Installations.

The report identifies any damage, deterioration, defects and/or conditions found by the inspector which may give rise to danger (see PART 5), together with any items for which improvement is recommended.

You should have received the report marked 'Original' and the contractor should retain a duplicate. If you were the person ordering this report, but not the owner or user of the installation, you should pass this report, or a full copy of it, including these notes, the schedules and additional pages (if any), immediately to the owner or user of the installation.

This report should be retained in a safe place and shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this report will provide the new user with an assessment of the condition of the electrical installation at the time the periodic inspection was carried out.

For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. NICEIC* recommends that you engage the services of an NICEIC contractor for the inspection. Only an NICEIC contractor is authorised to issue this NICEIC Electrical Installation Condition Report, which has a unique serial number that is traceable to the contractor to which it was supplied by NICEIC.

The recommended date by which the next inspection should be carried out is stated in PART 4 of this report. With the exception of domestic (household) premises, there should also be a notice at or near the main switchboard or distribution board/consumer unit indicating when the next inspection of the installation is due.

This report is intended to be issued only for the purpose of reporting on the condition of an existing electrical installation and must not be issued to certify new electrical installation work including the replacement of a distribution board or consumer unit.

The report consists of at least eight numbered pages. The report is only valid if the Schedule of Items Inspected (PART 9) has been completed to confirm that all relevant inspections have been carried out and the Schedule of Circuit Details (PART 11A) and the Schedule of Test Results (PART 11B) are attached. For installations having more than one distribution board (or consumer unit) or more circuits than can be recorded in PARTS 11A & 11B, one or more additional Schedule of Circuit Details and Schedule of Test Results, should form part of the report. Additional numbered pages may have been provided to permit further relevant information relating to the installation to be recorded. The report is invalid if any of the additional pages, listed in PART 10 are missing.

Where the installation includes a residual current device (RCD) it should be tested every six months by pressing the button marked "T" or "Test". The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions should be followed with respect to test button operation.

Where the installation includes a surge protection device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice.

Where the installation can be supplied by more than one source, such as the public supply and a standby generator or microgenerator, this should be identified in PART 7 Supply Characteristics and Earthing Arrangements, and the Schedules of Circuit Details and Schedule of Test Results (PARTS 11A & 11B) compiled accordingly.

PART 6 (Details and limitations) should identify fully the extent of the installation covered by this report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

Operational limitations may have been encountered during the inspection such as inability to gain access to parts of the installation or to an item of equipment. The inspector should have noted any such limitations in PART 6. It should be noted that the greater the limitations applying to a report, the less its value from the safety aspect.

A declaration should have been given by the inspector in PART 4 of the report. The declaration must reflect the statement given in PART 3, which summarises the observations and recommendations made in PART 5. Where one or more observations have been made in PART 5, the Classification code given to each by the inspector indicates the degree of urgency with which remedial action needs to be taken to restore the installation to a safe working condition.

Where the inspector has indicated an observation as code C1 (danger present) the safety of those using the installation is at risk. Wherever practicable, items classified as C1 should be made safe on discovery, and it is recommended that a skilled person(s) competent in electrical installation work undertakes the necessary remedial work immediately.

Where the inspector has indicated an observation as code C2 (potentially dangerous) the safety of those using the installation may be at risk, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.

Where the inspector has indicated that an item requires further investigation (FI), the investigation should be carried out without delay to determine whether danger or potential danger exists. For further guidance on the Classification codes, please see the reverse of page 2.

Where inadequacies in the intake equipment have been observed (Item 1 of PART 9), the person ordering the inspection should inform the distributor and/or supplier as appropriate.

Should the person ordering this report have reason to believe that it does not reasonably reflect the condition of the electrical installation reported on, that person should in the first instance raise the specific concerns in writing with the contractor. If the concerns remain unresolved, the person ordering this report may make a formal complaint to NICEIC, for which purpose a complaint form is available on request.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

For further information about electrical safety and how NICEIC can help you, visit:

www.niceic.com

* NICEIC is operated by Certsure LLP, a partnership between the Electrical Contractors' Association and the charity, Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).

GUIDANCE FOR RECIPIENTS ON THE CLASSIFICATION CODES

ONLY ONE CLASSIFICATION CODE SHOULD BE GIVEN FOR EACH RECORDED OBSERVATION

Classification code C1 (Danger present)

Where an observation has been given a Classification code C1, the safety of those using the installation is at risk and immediate remedial action is required.

The person responsible for the maintenance of the installation is advised to take action without delay to remedy the observed deficiency in the installation, or to take other appropriate action (such as switching off and isolating the affected part(s) of the installation) to remove the danger. The NICEIC contractor issuing this report will be able to provide further advice.

NICEIC makes available 'Electrical Danger Notification' forms to enable inspectors to record, and then to communicate to the person ordering the report, any dangerous condition discovered.

Classification code C2 (Potentially dangerous)

Classification code C2 indicates that, whilst those using the installation may not be at immediate risk, urgent remedial action is required to remove potential danger. The NICEIC contractor issuing this report will be able to provide further advice.

It is important to note that the recommendation given for the next inspection date in PART 4 of this report is conditional upon all items which have been given a Classification code C1 and code C2 being remedied immediately and as a matter of urgency, respectively.

It would not be reasonable for the inspector to indicate that the installation is in a satisfactory condition if any observation in this report has been given a code C1 or code C2 classification.

Classification code C3 (Improvement recommended)

Where an observation has been given a Classification code C3, the inspection and/or testing has revealed a non-compliance with the current safety standard which, whilst not presenting immediate or potential danger, would result in a significant safety improvement if remedied. Careful consideration should be given to the safety benefits of improving these aspects of the installation. The NICEIC contractor issuing this report will be able to provide further advice.

Code FI (Further investigation required without delay)

It should usually be possible for the inspector to attribute a Classification code to each observation without indicating a need for further investigation.

However, where 'FI' has been entered against an observation the inspector considers that further investigation of that observation is likely to reveal danger or potential danger that, due to the agreed extent or limitations of the inspection and/or testing (entered in PART 6), could not be fully identified at the time.

It would not be appropriate for the inspector to indicate that the installation is in a satisfactory condition if there is reasonable doubt as to whether danger or potential danger exists. Consequently, where the inspector has indicated 'Further investigation required without delay' (FI) the overall assessment of the installation (PART 3) should be marked as 'Unsatisfactory'.

If the inspector has indicated that an observation requires further investigation without delay, the person ordering this report is advised to arrange for the NICEIC contractor issuing the report (or another skilled person or persons competent in such work) to undertake further examination of that aspect of the installation as a matter of urgency, to determine whether or not danger or potential danger exists.

Further information

Further information on the application of Classification codes, primarily aimed at inspectors but of possible interest to persons ordering condition reports, can be found in Electrical Safety First's Best Practice Guide No 4 *Electrical installation condition reporting: Classification Codes for domestic and similar electrical installations*. The guide can be viewed or downloaded free of charge from www.electricalsafetyfirst.org.uk

For further information about electrical safety and how NICEIC can help you, visit
www.niceic.com

CORRIGENDA FACILITIES SERVICES

ELECTRICAL INSTALLATION CONDITION REPORT

**NUTFIELD C OF E PRIMARY SCHOOL - CARETAKERS HOUSE 158855.00
MID STREET SOUTH
NUTFIELD
REDHILL
SURREY
RH1 4JJ**

16 JANUARY 2025

CERTIFICATE NUMBER: 30961087/EICR18.3C

**THE RESULT OF THIS ELECTRICAL INSTALLATION
CONDITION REPORT IS: SATISFACTORY**

QUANTEC

1 THE OAKS BUSINESS VILLAGE, REVENGE ROAD, LORDSWOOD, CHATHAM,
KENT ME5 8LF TELEPHONE: 0300 303 4211 - EMAIL: ENQUIRIES@QUANTEC.LTD



INDEX

Survey Summary Sheet

Warning

Installation Summary

Section 1

Test Equipment Calibration Details

Section 2

Electrical Supply and Loading

Section 3

Bonding Details

Section 4

Schematic Drawing (if applicable)

Section 5

Mains Distribution System

Section 6

Test Result Schedules

Section 7-13

Accessory and Equipment Observations

Section 8

Fixed Equipment/Mechanical Panel Test Results (if applicable)

Section 14

Additional Information

Section 15A

Observations / Recommendations

Section 16

Abbreviations

Appendix 1

Copy of Circuit Charts (if applicable)

Appendix 2

Photographs (if applicable)

Appendix 3

Copy of NICEIC Periodic Test Certificate

Appendix 4

General Scope and Limitations of Testing (if applicable)

QUANTEC CONSULTANTS LIMITED
ELECTRICAL INSTALLATION CONDITION REPORT
SURVEY SUMMARY SHEET

CLIENT:	CORRIGENDA FACILITIES SERVICES
TEST & INSPECTION ADDRESS:	NUTFIELD C OF E PRIMARY SCHOOL - CARETAKERS HOUSE 158855.00 MID STREET SOUTH NUTFIELD REDHILL SURREY RH1 4JJ
FUNCTION OF PREMISES:	DOMESTIC (RENTED)
DATE OF INSPECTION:	16 JANUARY 2025
RECOMMENDED NEXT TEST DATE:	16 JANUARY 2030
INSPECTING ENGINEER:	J. PAINTER
PHOTOGRAPHS OF INSTALLATION PROVIDED:	NONE
GROSS INTERNAL AREA (SQ METRES):	NONE
APPROXIMATE AGE OF INSTALLATION:	20 YEARS

CONDITION OF INSTALLATION COVERED BY THIS REPORT
REFER TO SECTION 15A

CATEGORY CODE C1

CATEGORY CODE C2

CATEGORY CODE C3 **ü**CATEGORY CODE H&S **ü**CATEGORY CODE Information **ü**

CATEGORY CODE Lim

CATEGORY CODE F/I

CATEGORY CODE X

CATEGORY CODE DEFINITIONS FOR REMEDIAL WORKS

- | | |
|------------------|---|
| CODE 1 | - 'Danger present'. Risk of injury. Immediate remedial action required. |
| CODE 2 | - 'Potentially dangerous'. Urgent remedial action required. |
| CODE 3 | - 'Improvement recommended'. |
| CODE H&S | - Constitutes a possible Health & Safety hazard. |
| CODE Information | - Additional improvement may be required. |
| CODE Lim | - Indicates a Limitation |
| CODE F/I | - Further Investigation required without delay |
| CODE X | - Observed defects of Suppliers Equipment |

Attention: Any dangerous conditions will be reported to the client's site contact and Quantec Consultants Ltd office, and where possible be made safe at the time of inspection.

WARNING

**ANY NECESSARY WORK TO THIS INSTALLATION
SHOULD ONLY BE UNDERTAKEN BY A SUITABLY
QUALIFIED AND COMPETENT PERSON EXERCISING
CAUTION AND ACTING IN COMPLIANCE WITH THE
ELECTRICITY AT WORK REGULATIONS 1989.**

**BEFORE COMMENCING WORK ON ANY PART OF THE
ELECTRICITY SYSTEM - EQUIPMENT AND SERVICES
MUST BE ISOLATED, LOCKED OFF AND PROVED DEAD.**

**WARNING NOTICES SHOULD BE APPROPRIATELY
DISPLAYED AT SUCH TIMES.**

INSTALLATION SUMMARY	
MAINS DISTRIBUTION AND INCOMING SUPPLY	
The incoming 16mm ² XLPE/SWA supply cable and main distribution are of an adequate size and are in a reasonable condition.	
FINAL DISTRIBUTION	
The final circuit wiring is mainly T/E cables that are supplied from MCB distribution boards that are in a reasonable condition.	
ACCESSORIES	
The accessories inspected are generally in reasonable condition and appear to have been well maintained.	
EARTHING	
The earthing and bonding arrangements require upgrading to meet the requirements of BS7671:2018 + A2 2022.	
EQUIPMENT	
The equipment inspected is generally in a reasonable condition	
MAINTENANCE OF PHASE SEQUENCE	
N/A	
VOLTAGE DROP	
Throughout the installation the voltage drop complies with BS7671:2018 + A2 2022.	
ANY OTHER RELEVANT INFORMATION (i.e. areas not tested or not accessible)	
No adverse temperature values were recorded	
ANY DEVIATIONS OR EXCLUSIONS FROM REPORT	
The fire alarm system was excluded.	
The emergency lighting system was not fully tested to BS5266.	
It was not possible to verify the rating of the supply authority fuses due to access restrictions. The fuses were assumed to be rated at 100A.	
Any asbestos containing material (ACM) found during Inspection and Testing will be identified in the appropriate ACM box in the relevant section of the report. Further testing should be carried out after the asbestos has been removed. No dead testing will be carried out but, if possible, existing circuit descriptions will be used to allow live testing results to be obtained.	

SECTION 1 - TEST EQUIPMENT CALIBRATION DETAILS

TEST KIT No: 47

[illegible]

SECTION 2 - ELECTRICAL SUPPLY & LOADING						
Building: Caretakers Bungalow		Location (within building): Main Intake In Garage				
A. Supply details						Comments
Consumer tails:	16.0mm ² XLPE/SWA	Phase rotation correct:			N/A	
Main Earthing Conductor:	25.0mm ² PVC/PVC					
Earthing system:	TN-C-S					
B. Amps/Phase	L1	L2	L3	Single Phase	Comments	
1. Service Head				100		
2. Load readings taken				1.4		
3. Assumed load connected				20		
4. Spare capacity (1 minus 3)				80		
C. Voltage						
1. L1 Phase to Neutral						
2. L2 Phase to Neutral						
3. L3 Phase to Neutral						
4. Between Phases	L1-L2:	L2-L3:	L3-L1:	P-N: 241		
D. Line Earth Fault Loop Impedance (Ze) at Origin			Ze			
1. At or adjacent to service head (Ohms)			0.13			
E. Prospective Fault and Short Circuit Current at Origin			P-E	P-N	P-P	
1. Measured (state if calculated) (kA)			1.78	2.10	N/A (Calculated)	

SECTION 3 - BONDING DETAILS						
Building: Caretakers Bungalow						
A. Bonding of Services	Gas	Water	Oil	Lightning Protection	Structural Steel	Comments
1. Service installed	Yes	Yes	No	No	No	
2. Position	Garage Adjacent DB	Kitchen Under Sink	N/A	N/A	N/A	
3. Service bonded	Yes	Yes	N/A	N/A	N/A	
4. Location (within 600mm)	No	Yes	N/A	N/A	N/A	See 15A
5. Size & type of bond	16.0mm ² PVCS	16.0mm ² PVCS	N/A	N/A	N/A	
6. Condition (satisfactory)	Yes	Yes	N/A	N/A	N/A	
7. Continuity (Ω)	0.01	0.02	N/A	N/A	N/A	
B. Bonding						
Supplementary Bonding	1. Special locations	Satisfactory				
Water Meter	2. Meter installed	No				
	3. Bonded	N/A				

SECTION 5 - MAINS DISTRIBUTION SYSTEM

Location: Main Intake Position In Garage

[illegible]

Date: 16 January 2025

Tested by: J. PAINTER

Test Kit No: 47

[illegible]

SECTION 7 - SOCKET OUTLET TEST RESULTS

All socket outlets were inspected and tested

Yes

Provide details in section 15A of any faults / potentially dangerous items observed / items not tested during the test and inspection

SECTION 8 - FIXED EQUIPMENT TEST RESULTS10% of all fixed equipment was Inspected and Tested **including one from the extremity of each circuit****Yes**

Provide details in section 15A of any faults / potentially dangerous items observed / items not tested during the test and inspection

SECTION 9 - LUMINAIRES TEST RESULT10% of all luminaires were Inspected and Tested **including one from the extremity of each circuit****Yes**

Provide details in section 15A of any faults / potentially dangerous items observed / items not tested during the test and inspection

SECTION 10 - EXTERNAL LUMINAIRES TEST RESULTS10% of all external luminaires were Inspected and Tested **including one from the extremity of each circuit****Yes**

Provide details in section 15A of any faults / potentially dangerous items observed / items not tested during the test and inspection

SECTION 11 - FIRE ALARMS VISUAL INSPECTION

The fire alarm equipment was visually inspected only – Not tested to the requirements of BS5839

Yes

Provide details in section 15A of any faults / potentially dangerous items observed

SECTION 12 - EMERGENCY LIGHTING VISUAL INSPECTION

The emergency lighting equipment was visually inspected only – Not tested to the requirements of BS5266

Yes

Provide details in section 15A of any faults / potentially dangerous items observed

SECTION 13 - PORTABLE EQUIPMENT

The portable appliances were excluded from the survey

N/A

Provide details in section 15A of any faults / potentially dangerous items observed

SECTION 14 - ADDITIONAL INFORMATION

1.	Were there any areas not accessible?	No
2.	Is work by a Supply Authority required - Seepages of oil/compound, overloading of supply cables/metering etc?	No
3.	Is work by others required - painting/de-rusting requirement/repair of dampness/water seepage?	No
4.	Is the main switchgear/distribution equipment satisfactory and achieves necessary discrimination?	N/A
5.	Is the supply capacity adequate and is the load evenly balanced?	Yes
6.	Are there any signs of obsolescence/overheating throughout the main switchgear/sub-mains etc?	No
7.	Is switchgear labelled stating its function and downrating of fuses?	N/A
8.	Is clearance of rubbish necessary from switchroom/switchgear where reasonable access is required under Health and Safety at Work Act (1 metre clearance recommended at all times)?	No
9.	Are warning notices, phase indicators, treatment of electric shock notices fitted?	See 15A
10.	Are fire barriers to risers etc fitted?	See 15A
11.	Is rubber matting fitted adjacent to switchgear?	See 15A
12.	Are all earthing arrangements satisfactory - i.e. main earth, equipotential bonding and supplementary bonding?	Yes
13.	Do redundant cables/distribution equipment need to be removed?	No
14.	Is there maintained emergency lighting installed in riser/mains cupboard?	See 15A
15.	Are risers locked to prevent unauthorised access?	N/A
16.	Is all equipment fitted with an adequate means of local isolation?	Yes
17.	Are all mechanical interlocking devices operational?	N/A
18.	Are 400V, isolate elsewhere or two sources of supply labels fitted?	N/A
19.	Condition of containment, trunking, conduit and associated accessories?	Satisfactory
20.	Is a lightning protection system installed and is it bonded to the main earth system?	No - No
21.	Are there any other conditions likely to cause danger or be in breach of the Electricity at Work regulations 1989? If yes, please give details below.	No

COMMENTS:

NOTE: Any additional information relative to the installation to be added by the inspecting engineer as necessary, including any recommendations

SECTION 15A - OBSERVATIONS / RECOMMENDATIONS / BUDGET COSTS				
Ref No.	Section	Item	Comments	Category Code
1	GEN	1	A full risk assessment should be undertaken of this installation to determine the requirements for surge protection in accordance with BS 7671: 2018 + A2 2022.	Info.
2	GEN	2	Arc fault detection devices (AFDD) conforming to BS EN 62606 shall be provided for single-phase AC final circuits supplying socket-outlets with a rated current not exceeding 32A in: - Higher Risk Residential Buildings (HRRB) – A building more than 18m in height or six storeys, whichever is met first. - Houses in Multiple Occupation (HMO). - Purpose-built student accommodation. - Care homes. For all other premises, the use of AFDDs conforming to BS EN 62606 is recommended for single-phase AC final circuits supplying socket-outlets not exceeding 32A.	C3
3	GEN	3	Further Investigation is required throughout the installation to ensure appropriately coloured sleeving to all line and neutral conductors is present to comply with the current edition of BS7671.	Info.
4	GEN	4	A label has been fitted stating "CAUTION - This installation has wiring colours to two versions of BS 7671" but it is recommended that the existing green sleeving on CPCs is replaced to comply with the current edition of BS7671: 2018 + A2 2022.	Info.
5	3	A	At the Garage, reposition the protective conductor connection for the gas service to within 600mm of the entry point/meter to comply with the current edition of BS7671: 2018 + A2 2022.	C3
6	14	9	At the Main Intake Position, fit a 'Treatment of Electric Shock Notice'.	H&S
7	14	10	Further investigation is necessary to ensure all required fire barriers are installed, are in good condition and comply with the current edition of BS7671: 2018 + A2 2022.	C3
8	14	11	At the Main Intake Position, fit rubber matting adjacent to the main switchgear.	H&S
9	14	14	At the Main Intake, install an emergency light fitting to provide illumination in the event of a local power failure.	H&S

SECTION 16 - ABBREVIATIONS

GENERAL

1N	- Notifiable Category
ACU	- Air conditioner
ACM	- Asbestos-containing material
H&S	- Health and Safety
Htg	- Heating
I/O	- In order
IP	- Ingress protection
LHS	- Left-hand side
Lim	- Limitation
Ltg	- Lighting
Mh	- Mechanical (CPC)
N/A	- Not applicable
NNP	- No name plate
N/V	- Not verifiable
RHS	- Right-hand side
YOM	- Year of manufacture (estimated)

TEST RESULTS

EFLI	- Earth fault loop impedance
$I_{r,n}$	- Trip current
Info.	- Information only
I/R	- Insulation resistance
N/T	- No Trip
O/C	- Open circuit
PFC	- Prospective fault current
PSCC	- Prospective short circuit current
Zs	- EFLI

PROTECTIVE DEVICES

ACB	- Air circuit breaker to BS 3871 Part 2
Adj	- Adjustable
AFDD	- Arc Fault Detection Device
C/R	- Cartridge fuse to BS1361 and 1363
C/W	- Copper wire
R/W	- Rewirable fuse to BS3036
HRC	- High rupturing capacity fuse to BS88 (BS EN 60268-1)
MCB	- Miniature circuit breaker to BS 3871 Part 1 (BS EN 60898) (BS EN 60947) (State type & 'M' Rating)
MCCB	- Moulded case circuit breaker to BS3871 Part 2 (BS EN 60947)
RCBO	- Residual current circuit breaker (combined MCB/RCD) (BS EN 61009)
RCD	- Residual current device (no overcurrent protection) (BS 4293)
SPD	- Surge Protective Device

CABLE TYPES

Al	- Aluminium
FP200	- Fire proof 200°C
FP400	- Fire proof 400°C
HR	- Heat resistant flexible
LSF	- Low smoke and fume
LSZHS	- Low smoke zero halogen screened
MICC	- Mineral insulated non covered
MICV	- Mineral insulated PVC covered
OTHER	- Cords etc.
PILC	- Paper impregnated lead covered
PVC/PVC	- PVC Single core PVC insulated
PVCS	- PVC Single core
RIS	- Rubber insulated fabric covered
SWA	- Steel wire armoured
SY	- Armoured flexible
T/E	- Twin and earth
TRS	- Tough rubber sheathed
VIR	- Vulcanised insulated rubber
XLPE	- Cross linked polyurethane

SOCKET OUTLETS

S/O	- Socket outlet(s) (general)
-----	------------------------------

DISTRIBUTION

cct	- Circuit
CONT	- Contactor
CPC	- Circuit protective conductor
C/T	- Current transformer
DB	- Distribution board
DP	- Double Pole
EMB	- Earth Marshalling Bar
F/S	- Fused switch (BS EN 60947-3)
FCU	- Fused connection unit
GPL	- General power & lighting
ISO	- Isolator (BS EN 60947)
MET	- Main Earthing Terminal
PERM	- Maximum permissible value
PWR	- Power
REC	- Recorded
S/F	- Switch fuse (BS EN 60269)
T/S	- Time switch

LUMINAIRES

BD	- Bulkhead
EL	- Emergency lighting
ExL	- External lighting
FF	- Fluorescent fitting
LV	- Low voltage
MN	- Maintained
NM	- Non maintained
VP	- Vapour proof

QUANTEC CONSULTANTS LTD - DISTRIBUTION BOARD CHART

Site: NUTFIELD C OF E PRIMARY SCHOOL - CARETAKERS HOUSE 158855.00

Location: Main Intake Position In Garage

Phase SPN

Client D/B Ref: None (6/14)

Zs(DB) 0.13 Ω

Supplied From: Item (5/13)

PSCC 2.10 kA

Way	Rating	Cable mm ² Type	Circuit description
1	80A RCD		30mA RCD For Circuit 3 - 9
2	80A RCD		30mA RCD For Circuit 3 - 9
3	32A MCB	6 T/E	ISO - Cooker Kitchen (Within Unit)
4	32A MCB	2x2.5 T/E	S/O & FCU - Entrance Hallway, Living Room & Kitchen
5	16A MCB	2.5 T/E	S/O - Garage
6	6A MCB	1.5 T/E	Ltg - Bedrooms & Hall Adjacent
7	40A MCB		Spare
8			Spare
9			Spare
10	80A RCD		30mA RCD For Circuit 12 - 18
11	80A RCD		30mA RCD For Circuit 12 - 18
12	32A MCB	2x2.5 T/E	S/O - Bedrooms & Hall Adjacent
13	16A MCB	2.5 T/E	FCU - Immersion Heater - Hall Adjacent Bedrooms Cupboard
14	6A MCB	1.5 T/E	Ltg - Entrance Hallway, Living Room & Kitchen
15	6A MCB	1.5 T/E	Ltg - Garage
16			Spare
17			Spare
18			Spare