



Commercial Catering Inspection Record

Registered Business/engineer details can be checked at www.gassaferegister.co.uk or by calling 0800 408 5500

Cert No.
No. 0010
No. Appliances
2

Company / Installer		Inspection / Installation Address		Landlord / Agent / Customer	
Engineer	Gary Burnell	Name	Nutfield Church Primary School	Name	Nutfield Church Primary School
Company	True Heating Solutions Ltd	Address	59 Mid Street South Nutfield Surrey	Company Name	
Address	82 Burwash Road Crawley West Sussex RH10 6LF			Address	59 Mid Street South Nutfield Surrey
Tel No.	07834151341	Postcode	RH1 4JJ		
Gas Safe Reg.	637840	Mobile		Postcode	RH1 4JJ
ID Card No.	5939079	Landline	01737 823239	Email	sbm@nutfield.surrey.sch.uk
Email	trueheatingsolutions@hotmail.com	Email	sbm@nutfield.surrey.sch.uk	Phone	
		Unique Property Reference Number		Unique Property Reference Number	
Gas Installation Details		Ventilation/extract system		Risk analysis of kitchen ventilation system Has risk assessment in accordance with IGEN/UP/19 been applied No If applicable what is the outcome of the Risk Assessment -	
Emergency isolation for catering area provided	Yes	Is a canopy system installed	Yes		
If yes - location satisfactory	Yes	If yes - is the canopy overhang correct	Yes		
If yes - is it accessible	Yes	Record type of filtration (e.g. mesh/baffles/UV)	Baffles		
If Yes - is valve of suitable type	Yes	Filtration adequately maintained	Yes		
If Yes - is valve handle secured in place	Yes	Mechanical extract provided	Yes		
Labels affixed	Yes	If yes - what is the flow rate litres/sec	3.4		
Emergency notice present	Yes	If yes - is flow rate adequate	Yes		
Gas isolation via automatic electric system	Yes	Is mechanical extract interlocked with gas supply	Yes		
If yes - is the system fitted with automatic pressure proving	No	Is interlock fitted with manual override	No		
If yes - do all appliance burners have flame safeguards	Yes	If yes, override disabled	N/A		
Alternatively, is the system manually reset	N/A	If no, written report provided advising against use	N/A		
If yes - is there an attached notice regarding resetting	N/A	Mechanical ventilation fitted	Yes		
Is there evidence of corrosion of gas pipework	No	If yes - what is the flow rate in litres/sec	3.4		
Action required	N/A	If yes and where appropriate - is the flow rate adequate	Yes		
Gas installation has been tightness tested	Yes	If yes, mechanical ventilation interlock provided	Yes		
If yes - Is the gas installation tightness satisfactory	Yes	If yes, does the interlock work correctly	Yes		
Pipework within the catering area		Where required is natural ventilation provided	N/A		
Are the correct materials in use	Yes	Provide details - high level (cm2)	N/A		
Is the pipework correctly identified / labelled	Yes	Provide details - low level (cm2)	N/A		
Correctly supported throughout	Yes	Are adequate notices regarding ventilation provided	Yes		
Are pipe sleeves extend through walls/floors etc	Yes	Automatic means of CO ₂ detection provided	N/A		
Suitable purge points fitted	Yes	If yes, is detection interlocked with gas supply	N/A		
Suitable test points fitted	Yes	Air Quality Testing (in accordance with IGEN/UP/19)			
Main protective equipotential bond fitted	Yes	First CO ₂ reading (ppm)	996		
Safety Information		Second CO ₂ reading (ppm)	1036		
Has a Warning/Advisory Record been issued	N/A	Third CO ₂ reading (ppm)	1096		
Have warning labels been affixed	N/A	Average of above readings	1042		
Has a responsible person been advised	N/A	Results of air quality testing	Acceptable		
Classification	NA	Details of record instrument(s)			
Serial No.	-	1) Make/Model	AZ7755		
Risk Analysis of kitchen ventilation system		1) Calibration date	N/A		
Has risk assessment in accordance with HSE Catering Information Sheet 23 (CAIS 23) been applied	No	2) Make/Model	Printer/TL017-EN P1-3		
If applicable what is the outcome of the Risk Assessment	-	2) Calibration date	N/A		

Appliance Details									Inspection Details														
#	Type	Make	Model	Serial No.	GCN	Location	Flue Type	Landlord Appliance	Manufacturers instructions available (Yes/No)	Operating pressure (mbar)	Heat input (kW/h)	FSD Fitted to all burners (Yes/No/NA)	All appliance safety devices (including FSD's) operating correctly (Yes/No/NA)	Adequate ventilation arrangements (Yes/No/NA)	Adequate flueing/extract arrangement	Maximum CO reading above appliance (if applicable)	Maximum CO2 reading above appliance (if applicable)	Gas isolation valve fitted (Yes/No)	Gas hose and required restraint fitted correctly (Yes/No/NA)	Pipework gas tight (Yes/No)	Safe to use (Yes/No)		
1	Oven	Falcon	G3106	F667161	N/A	Kitchen	FL	Yes	Yes	20mbar	44.8kw	Yes	Yes	Yes	Yes	0	2	Yes	Yes	Yes	Yes		
2	Steamer	Convotherm	C4eD 10.10 GB	YB300022A2AAAA	N/A	Kitchen	OF	Yes	Yes	20mbar	21kw	Yes	Yes	Yes	Yes	12	9.34	Yes	Yes	Yes	Yes		
3																							
4																							
5																							
6																							
7																							
8																							
9																							
10																							
11																							
Additional Works																							
None																							
Additional Comments																							
All okay																							
Signatures																							
Signed									Received By									Date			15/12/2025		
Print Name			Gary Burnell						Print Name			John						Next Inspection Date			15/12/2026		
Declaration of Gas Safety - I confirm that this record is true and accurate representation of the gas work carried out on the day of inspection. Relevant and appropriate duty-holders are require to ensure that gas appliances, installation pipework and flues are maintained in a safe condition so as to prevent the risk of injury to any person.																							