

Display energy certificate (DEC)



HM Government

Surrey County Council
Nutfield Church Primary School
Mid Street
SOUTH NUTFIELD
RH1 4JJ

Operational rating

B

Certificate number: 2478-1090-1250-0098-1225

Valid until: 30 September 2026

Total useful floor area: 1,444 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Previous operational ratings

Date	Operational rating
October 2025	46 B

Score	Operational rating	This building	Typical
0-25	A		
26-50	B	46 B	
51-75	C		
76-100	D		
----- 100 -----			
101-125	E		
126-150	F		
150+	G		

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
October 2025	18	15	0

Assessment details

Assessor's name	Nathan Overton
Employer/Trading name	Socotec UK LTD
Employer/Trading address	Socotec, Leofric Business Park, Progress Way, Coventry, CV3 2TF
Assessor's declaration	Not related to the occupier.
Accreditation scheme	Elmhurst Energy Systems Ltd
Issue date	26 November 2025
Nominated date	1 October 2025

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	23.18	53.10
Typical energy use (kWh/m ² /year)	40	146.49
Energy from renewables	0%	0%